UTILITY CONSTRUCTION

GENERAL NOTES:

- 1. THE PROPOSED UTILITY CONSTRUCTION SHALL MEET THE APPLICABLE REQUIREMENTS OF THE NC DEPARTMENT OF TRANSPORTATION'S "STANDARD SPECIFICATIONS FOR ROADS AND STRUCTURES" DATED JANUARY 2012.
- 2. THE EXISTING WATER LINES BELONG TO THE CITY OF CONCORD. THE EXISTING SEWER LINES BELONG TO THE CITY OF CONCORD AND WSACC AS NOTED ON THE PLANS
- 3. ALL WATER LINES TO BE INSTALLED
 WITHIN COMPLIANCE OF THE RULES AND
 REGULATIONS OF THE NORTH CAROLINA
 DEPARTMENT OF ENVIRONMENTAL AND NATURAL
 RESOURCES, DIVISION OF WATER RESOURCES,
 PUBLIC WATER SUPPLY SECTION. ALL SEWER
 LINES TO BE INSTALLED WITHIN COMPLIANCE
 OF THE RULES AND REGULATIONS OF THE
 NORTH CAROLINA DEPARTMENT OF
 ENVIRONMENT AND NATURAL RESOURCES,
 DIVISION OF WATER RESOURCES, WATER
 QUALITY SECTION. PERFORM ALL WORK IN
 ACCORDANCE WITH THE APPLICABLE PLUMBING
 CODES.
- 4. THE UTILITY OWNER OWNS THE EXISTING UTILITY FACILITIES AND WILL OWN THE NEW UTILITY FACILITIES AFTER ACCEPTANCE BY THE DEPARTMENT. THE DEPARTMENT OWNS THE CONSTRUCTION CONTRACT AND HAS ADMINISTRATIVE AUTHORITY. COMMUNICATIONS AND DECISIONS BETWEEN THE CONTRACTOR AND UTILITY OWNER ARE NOT BINDING UPON THE DEPARTMENT OR THIS CONTRACT UNLESS AUTHORIZED BY THE ENGINEER. AGREEMENTS BETWEEN THE UTILITY OWNER AND CONTRACTOR FOR THE WORK THAT IS NOT PART OF THIS CONTRACT OR IS SECONDARY TO THIS CONTRACT ARE ALLOWED, BUT ARE NOT BINDING UPON THE DEPARTMENT.
- 5. PROVIDE ACCESS FOR THE DEPARTMENT PERSONNEL AND THE OWNER'S REPRESENTATIVES TO ALL PHASES OF CONSTRUCTION. NOTIFY DEPARTMENT PERSONNEL AND THE UTILITY OWNER TWO WEEKS PRIOR TO COMMENCEMENT OF ANY WORK AND ONE WEEK PRIOR TO SERVICE INTERRUPTION. KEEP UTILITY OWNERS' REPRESENTATIVES INFORMED OF WORK PROGRESS AND PROVIDE OPPORTUNITY FOR INSPECTION OF CONSTRUCTION AND TESTING.

- 6. THE PLANS DEPICT THE BEST AVAILABLE INFORMATION FOR THE LOCATION, SIZE, AND TYPE OF MATERIAL FOR ALL EXISTING UTILITIES. MAKE INVESTIGATIONS FOR DETERMINING THE EXACT LOCATION, SIZE, AND TYPE MATERIAL OF THE EXISTING FACILITIES AS NECESSARY FOR THE CONSTRUCTION OF THE PROPOSED UTILITIES AND FOR AVOIDING DAMAGE TO EXISTING FACILITIES. REPAIR ANY DAMAGE INCURRED TO EXISTING FACILITIES TO THE ORIGINAL OR BETTER CONDITION AT NO ADDITONAL COST TO THE DEPARTMENT.
- 7. MAKE FINAL CONNECTIONS OF THE NEW WORK TO THE EXISTING SYSTEM WHERE INDICATED ON THE PLANS, AS REQUIRED TO FIT THE ACTUAL CONDITIONS, OR AS DIRECTED.
- 8. MAKE CONNECTIONS BETWEEN EXISTING AND PROPOSED UTILITIES AT TIMES MOST CONVENIENT TO THE PUBLIC, WITHOUT ENDANGERING THE UTILITY SERVICE, AND IN ACCORDANCE WITH THE UTILITY OWNER'S REQUIREMENTS. MAKE CONNECTIONS ON WEEKENDS, AT NIGHT, AND ON HOLIDAYS IF NECESSARY.
- 9. ALL UTILITY MATERIALS SHALL BE APPROVED PRIOR TO DELIVERY TO THE PROJECT. SEE 1500-7, "SUBMITTALS AND RECORDS" IN SECTION 1500 OF THE STANDARD SPECIFICATIONS.

PROJECT SPECIFIC NOTES:

- 1. ALL TRENCH INSTALLED WATER LINE, 4-INCHES THROUGH 24-INCHES SHALL BE DUCTILE IRON THICKNESS CLASS 50, EXCEPT WHERE NOTED ON THE PLANS.
- 2. ALL WATER LINE FITTINGS 4-INCHES THROUGH 24- INCHES IN DIAMETER, SHALL BE PRESSURE CLASS 350 DUCTILE IRON RESTRAINED JOINT IN ACCORDANCE WITH ANSI A21.10 / AWWA C110 AND ANSI A21.4 / AWWA C104.
- 3. ALL TRENCHLESS INSTALLED WATER LINE PLACED BY DIRECTIONAL DRILLING SHALL BE 22" 250PSI HDPE DR9 TO CLOSELY MATCH INSIDE DIAMETER OF 16" D.I.P. ALL TRENCHLESS INSTALLED WATER LINE PLACED BY OTHER METHODS SHALL BE DUCTILE IRON THICKNESS CLASS 51 WITH CASING PIPE AND CASING SPIDERS.
- 4. CONTRACTOR 'S ATTENTION IS DIRECTED TO SECTIONS 102, 107, AND 1550 OF THE STANDARD SPECIFICATIONS CONCERNING TRENCHLESS INSTALLATION. IT IS CONTRACTORS RESPONSIBILITY TO HAVE BORE PATH DESIGNED AND SEALED BY A LICENSED NORTH CAROLINA ENGINEER. NO DAMAGE IS ALLOWED TO RIVER, WETLANDS, OR BUFFER ZONES.
- 5. PROVIDE THRUST RESTRAINT ON THE EXISTING WATER LINE WHERE TIE -INS ARE MADE AS NECESSARY.
- 6. CONTRACTOR SHALL NOT OPERATE ANY VALVES ON THE EXISTING UTILITY SYSTEMS. CONTRACTOR SHALL CONTACT THE UTILITY OWNER TO CONDUCT STRATEGIC OPERATION OF VALVES FOR SERVICE INTERRUPTION IN ORDER TO PERFORM SPECIFIC WORK.
- 7. ALL VALVES 12" AND UNDER SHALL BE RESILIENT WEDGE GATE VALVES.
- 8. ALL VALVES 14" AND LARGER SHALL BE BUTTERFLY VALVES.
- 9. ENSURE THAT ALL EXISTING MANHOLE RIMS ARE LOCATED OUTSIDE OF PROPOSED DRAINAGE DITCHES. ROTATE CONE IF NECESSARY.

PROJECT REP	EKENCE	NU•	SHEET NO.
B-51	23		UC-3
DESIGNED BY:	всн		WITH CAN'
DRAWN BY:	всн	,,,,,,	OFESSION
CHECKED BY:	JĿT	Doc	uSigned-b _W : Δ I
APPROVED BY:	MRB	Bob	by Gliggettouser
REVISED:		OBF	A26F63564434
NORTH CAROLINA DEPARTMENT OF TRANSPORTATION		2/3/2016	
UTILITIES ENGINEE PHONE: (919)70 FAX: (919)250-	7-6690	UTILI	TY CONSTRUCTION PLANS ONLY
TGS ENGINEERS 804-C N. LAFAYETTE ST SHELBY, NC 28 150 PH (704) 476-0003 CORP. LICENSE NO.: C-0275			

Jensting of the dispension of the carried of the carried of the contract of the carried of the c