



## PARTIAL ELEVATION


SHOWING WELDED WIRE FENCE DETAILS STAR DETAIL NOT SHOWN FOR CLARITY. FOR STAR DETAIL. SEE "CONCRETE PARAPET STAR DETAIL" SHEET



## PARTIAL ELEVATION

SHOWING ORNAMENTAL FENCE POST LOCATIONS (WELDED WIRE NOT SHOWN) STAR DETAIL NOT SHOWN FOR CLARITY. FOR STAR DETAIL. SEE "CONCRETE PARAPET STAR DETAIL" SHEET





NOTES

ORNAMENTAL FENCE SHALL BE 2"X 2"BLACK WELDED WIRE OR APPROVED EQUAL.

ORNAMENTAL FENCE, VERTICAL FENCE POSTS, 2"PLATES, AND BASE PLATES SHALL BE

ALL BOLTS SHALL BE HILTI  $\frac{1}{8}$ " Ø HAS-E HDG ANCHOR ROD WITH HILTI HIT HY 200 (7\%"MIN. EMBEDMENT) OR APPROVED EQUAL.

POST SHALL BE SPACED TO BE A MINIMUM OF 1'-6" FROM BARRIER RAIL EXPANSION JOINT.

FOR ORNAMENTAL FENCE, SEE SPECIAL PROVISIONS.

AFTER A SHADE OF BLACK HAS BEEN SELECTED FOR THE FENCING. THE CONTRACTOR SHALL SUBMIT A SAMPLE OF COMPATIBLE EXTERIOR ACRYLIC HOUSE PAINT TO THE ENGINEER. THIS PAINT SHALL MATCH THE FENCING COLOR AS CLOSELY AS POSSIBLE. AFTER ERECTION OF THE FENCING, ALL EXPOSED ANCHOR BOLTS, NUTS, WASHERS, MACHINE SCREWS, CAP SCREWS, BOLTS, ATTACHMENT BRACKETS, HOLD-DOWN PLATES, AND BUILT UP ANGLES SHALL BE COATED WITH TWO COATS OF THIS PAINT. FENCE COMPONENTS SHALL BE PAINTED AFTER GALVANIZATIONS IN ACCORDANCE WITH SECTION 442 OF THE STANDARD SPECIFICATIONS.

ADHERE TO THE APPLICABLE REQUIREMENTS OF SECTION 1074 OF THE STANDARD SPECIFICATIONS.

POSTS, BASE PLATES, AND CONNECTOR PLATES SHALL MEET THE REQUIREMENTS FOR AASHTO M270 GRADE 50 AND SHALL BE GALVANIZED IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS.

BOLTS SHALL CONFORM TO THE REQUIREMENTS OF ASTM A307 AND NUTS SHALL CONFORM TO THE REQUIREMENTS OF AASHTO M291. BOLTS, NUTS, AND WASHERS SHALL BE GALVANIZED. AT THE CONTRACTOR'S OPTION, STAINLESS STEEL BOLTS, NUTS, AND WASHERS MAY BE USED AS AN ALTERNATE FOR THE GALVANIZED BOLTS, NUTS, AND WASHERS. THEY SHALL CONFORM TO OR EXCEED THE MECHANICAL REQUIREMENTS OF ASTM A307. THE USE OF THIS ALTERNATE SHALL BE APPROVED BY THE ENGINEER.

WIRE MESH FENCE SHALL CONFORM TO THE REQUIREMENTS OF ASTM F2453 TYPE 2.

THE CONTRACTOR SHALL VERIFY THE DIMENSIONS AND POST SPACINGS IN THE FIELD PRIOR TO FABRICATION AND INSTALLATION OF FENCE.

PAY LENGTH =  $\underline{\phantom{a}^{237.2}}$  LIN. FT.

B-4490 PROJECT NO. \_\_\_ CUMBERLAND COUNTY STATION: 35+23.40 -L-



Kut Z. W. arford 3/29/2016

STATE OF NORTH CAROLINA DEPARTMENT OF TRANSPORTATION SUPERSTRUCTURE ORNAMENTAL FENCE DETAILS

SHEET NO REVISIONS S-65 DATE: DATE: DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED TOTAL SHEETS

STR.#2

T.L. AVERETTE \_ DATE : <u>06-15</u> DRAWN BY : \_\_ DATE : <u>07-15</u> J.P. ADAMS CHECKED BY : \_ DESIGN ENGINEER OF RECORD: T.L. AVERETTE DATE: 09-15