

FOUNDATION LAYOUT

NOTES

ALL END BENT PILES ARE VERTICAL HP 14 x 73 STEEL PILES. DIMENSIONS LOCATING PILES ARE SHOWN TO PILE CENTERLINES AT THE BOTTOM OF THE END BENT CAPS.

FOR PILES, SEE GEOTECHNICAL SPECIAL PROVISIONS AND SECTION 450 OF THE STANDARD SPECIFICATIONS.

PILES AT END BENT 1 AND END BENT 2 ARE DESIGNED FOR A FACTORED RESISTANCE OF 110 TONS PER PILE.

DRIVE PILES AT END BENT 1 AND END BENT 2 TO A REQUIRED DRIVING RESISTANCE OF 185 TONS PER PILE.

PILES AT END BENT 1 AND END BENT 2 ARE TO BE DRIVEN AFTER CONSTRUCTION AND RELEASE OF THE MSE WALLS PENDING THE SETTLEMENT MONITORING PROGRAM.

TESTING PILES WITH THE PDA DURING DRIVING, RESTRIKING OR REDRIVING MAY BE REQUIRED. THE ENGINEER WILL DETERMINE THE NEED FOR PDA TESTING. FOR PDA TESTING, SEE SECTION 450 OF THE STANDARD SPECIFICATIONS.

CORRUGATED METAL CANS AT END BENT 1 AND END BENT 2 ARE TO BE PLACED DURING CONSTRUCTION IN THE REINFORCED BACKFILL OF THE MSE WALLS. SEE MSE WALL PLANS.

INSTALLATION OF CORRUGATED METAL CANS FROM THE BOTTOM OF THE PILE CAP TO THE LEVELING PAD ELEVATION IS REQUIRED FOR PILES AT END BENT 1 AND END BENT 2. THE CANS SHALL BE DESIGNED TO WITHSTAND THE PRESSURES FROM COMPACTION OPERATIONS ON ADJACENT FILLS WITHOUT DISTORTION. AT A MINIMUM, CORRUGATED METAL CANS SHALL BE 16-GAUGE WITH A WALL THICKNESS OF 0.064".

LOOSELY BACKFILL CORRUGATED METAL CANS USING SAME MATERIAL AS MSE REINFORCEMENT ZONE PRIOR TO CONSTRUCTION OF THE END BENT PILE CAP. DO NOT COMPACT MATERIAL WITHIN THE CAN.

OBSERVE A ONE MONTH WAITING PERIOD AFTER CONSTRUCTION OF THE MSE WALLS BEFORE DRIVING PILES. DO NOT DRIVE PILES AT END BENT 1 AND END BENT 2 UNTIL THE WALL HAS BEEN RELEASED FOLLOWING THE SETTLEMENT MONITORING PROGRAM.

FOR SURCHARGES AND WAITING PERIODS, SEE SECTION 235 OF THE STANDARD SPECIFICATIONS AND THE SURCHARGES AND WAITING PERIODS PROVISION.

PROJECT NO. I-4729A
POLK COUNTY
 STATION: 22+87.20 -RP_E-


SHEET 2 OF 4

STATE OF NORTH CAROLINA
 DEPARTMENT OF TRANSPORTATION
 RALEIGH

GENERAL DRAWING
BRIDGE OVER
RAMP (-E_CONN_REV-) ON
RAMP (-RP_E-) BETWEEN
I-26 AND US 74

REVISIONS						SHEET No.
No.	BY:	DATE:	No.	BY:	DATE:	S1-2
1			3			TOTAL SHEETS
2			4			24

DOCUMENT NOT CONSIDERED FINAL
 UNLESS ALL SIGNATURES COMPLETED



PLANS PREPARED BY :
PARSONS
 5540 CenterView Drive, Suite 217
 Raleigh, NC 27606-3386
 NC LICENSE No. F-0246
 FOR NORTH CAROLINA DEPARTMENT OF TRANSPORTATION

DRAWN BY :	K. E. LOFTON	DATE :	5-17
CHECKED BY :	A. D. SHAH	DATE :	7-17
DESIGN ENGINEER :	A. D. SHAH	DATE :	8-17