

UTILITY CONSTRUCTION

DOCUMENT NOT CONSIDERED FINAL
UNTIL ALL SIGNATURES ARE COMPLETED

Michael Baker Engineering, Inc.
8000 Regency Pkwy
Suite 600
Cary, NC 27518
NC License: F-1084

Michael Baker
INTERNATIONAL

PROJECT REFERENCE NO.	SHEET NO.
U-5935	UC-3
DESIGNED BY:	
DRAWN BY:	
CHECKED BY:	
APPROVED BY:	
REVISED:	
NORTH CAROLINA DEPARTMENT OF TRANSPORTATION	
UTILITIES ENGINEERING SEC. PHONE: (919) 707-6690 FAX: (919) 250-4151	
UTILITY CONSTRUCTION PLANS ONLY	

GENERAL NOTES:

1. THE PROPOSED UTILITY CONSTRUCTION SHALL MEET THE APPLICABLE REQUIREMENTS OF THE NC DEPARTMENT OF TRANSPORTATION'S "STANDARD SPECIFICATIONS FOR ROADS AND STRUCTURES" DATED JANUARY 2012.
2. THE EXISTING UTILITIES BELONG TO THE CITY OF WILSON .
3. ALL WATER LINES TO BE INSTALLED WITHIN COMPLIANCE OF THE RULES AND REGULATIONS OF THE NORTH CAROLINA DEPARTMENT OF ENVIRONMENTAL QUALITY, DIVISION OF WATER RESOURCES, PUBLIC WATER SUPPLY SECTION. ALL SEWER LINES TO BE INSTALLED WITHIN COMPLIANCE OF THE RULES AND REGULATIONS OF THE NORTH CAROLINA DEPARTMENT OF ENVIRONMENTAL QUALITY, DIVISION OF WATER RESOURCES, WATER QUALITY SECTION. PERFORM ALL WORK IN ACCORDANCE WITH THE APPLICABLE PLUMBING CODES.
4. THE UTILITY OWNER OWNS THE EXISTING UTILITY FACILITIES AND WILL OWN THE NEW UTILITY FACILITIES AFTER ACCEPTANCE BY THE DEPARTMENT. THE DEPARTMENT OWNS THE CONSTRUCTION CONTRACT AND HAS ADMINISTRATIVE AUTHORITY. COMMUNICATIONS AND DECISIONS BETWEEN THE CONTRACTOR AND UTILITY OWNER ARE NOT BINDING UPON THE DEPARTMENT OR THIS CONTRACT UNLESS AUTHORIZED BY THE ENGINEER. AGREEMENTS BETWEEN THE UTILITY OWNER AND CONTRACTOR FOR THE WORK THAT IS NOT PART OF THIS CONTRACT OR IS SECONDARY TO THIS CONTRACT ARE ALLOWED, BUT ARE NOT BINDING UPON THE DEPARTMENT.
5. PROVIDE ACCESS FOR THE DEPARTMENT PERSONNEL AND THE OWNER'S REPRESENTATIVES TO ALL PHASES OF CONSTRUCTION. NOTIFY DEPARTMENT PERSONNEL AND THE UTILITY OWNER TWO WEEKS PRIOR TO COMMENCEMENT OF ANY WORK AND ONE WEEK PRIOR TO SERVICE INTERRUPTION. KEEP UTILITY OWNERS' REPRESENTATIVES INFORMED OF WORK PROGRESS AND PROVIDE OPPORTUNITY FOR INSPECTION OF CONSTRUCTION AND TESTING.

6. THE PLANS DEPICT THE BEST AVAILABLE INFORMATION FOR THE LOCATION, SIZE, DEPTH, AND TYPE OF MATERIAL FOR ALL EXISTING UTILITIES. MAKE INVESTIGATIONS FOR DETERMINING THE EXACT LOCATION, SIZE, AND TYPE MATERIAL OF THE EXISTING FACILITIES AS NECESSARY FOR THE CONSTRUCTION OF THE PROPOSED UTILITIES AND FOR AVOIDING DAMAGE TO EXISTING FACILITIES. REPAIR ANY DAMAGE INCURRED TO EXISTING FACILITIES TO THE ORIGINAL OR BETTER CONDITION AT NO ADDITIONAL COST TO THE DEPARTMENT.
7. MAKE FINAL CONNECTIONS OF THE NEW WORK TO THE EXISTING SYSTEM WHERE INDICATED ON THE PLANS, AS REQUIRED TO FIT THE ACTUAL CONDITIONS, OR AS DIRECTED.
8. MAKE CONNECTIONS BETWEEN EXISTING AND PROPOSED UTILITIES AT TIMES MOST CONVENIENT TO THE PUBLIC, WITHOUT ENDANGERING THE UTILITY SERVICE, AND IN ACCORDANCE WITH THE UTILITY OWNER'S REQUIREMENTS. MAKE CONNECTIONS ON WEEKENDS, AT NIGHT, AND ON HOLIDAYS IF NECESSARY. COORDINATE ALL SERVICE INTERRUPTIONS AND CONNECTIONS WITH THE UTILITY OWNER.
9. ALL UTILITY MATERIALS SHALL BE APPROVED PRIOR TO DELIVERY TO THE PROJECT. SEE 1500-7, " SUBMITTALS AND RECORDS" IN SECTION 1500 OF THE STANDARD SPECIFICATIONS.
10. CONTRACTOR TO COORDINATE UTILITY CONSTRUCTION WORK WITH OTHER DISCIPLINES OF WORK AFFECTING SUBSURFACE CONDITIONS INCLUDING BUT NOT LIMITED TO SIGNING, SIGNALS AND DRAINAGE.

PROJECT SPECIFIC NOTES:

1. CONTRACTOR'S ATTENTION IS DIRECTED TO THE UTILITY CONSTRUCTION PROJECT SPECIAL PROVISIONS PROVIDED ALONG WITH THIS PLAN SET.
2. PROPOSED WATER LINE FROM -L- LINE STATION 17+47 TO -L- LINE STATION 88+12 INCLUDING ALL BRANCH WATER MAINS SHALL BE D.I. (DUCTILE IRON) PIPE.
3. MECHANICAL JOINT RESTRAINT SHALL BE USED FOR THE SPECIFIED NUMBER OF PIPE JOINTS ON BOTH SIDES OF FITTINGS, VALVES, ETC AS SHOWN IN THE TABLE ON SHEET UC-3E.

4. IN ALL LOCATIONS WHERE A PROPOSED WATER LINE IS TIEING TO AN EXISTING LINE A THRUST COLLAR SHALL BE INSTALLED.
5. ALL WATER LINE FITTINGS SHALL BE DUCTILE IRON, MECHANICAL JOINT OR RESTRAINED JOINT COMPACT FITTINGS.
6. EXISTING APPURTENANCES TO BE REMOVED SHALL NOT BE USED AS NEW MATERIALS IN THE PROPOSED CONSTRUCTION AND ALL APPURTENANCES TO BE REMOVED WILL BE THE PROPERTY OF THE OWNER AND DELIVERED TO THE CITY OF WILSON WATER RESOURCES DEPARTMENT.
7. ALL UTILITY LINES TO BE ABANDONED SHALL BE FILLED WITH FLOWABLE FILL.
8. REMOVAL, HANDLING, AND DISPOSAL OF ASBESTOS CEMENT PIPE SHALL BE PERFORMED IN ACCORDANCE WITH APPLICABLE EPA AND OSHA REGULATIONS AND APPLICABLE FEDERAL, STATE, AND LOCAL REGULATIONS.

9. CONTRACTOR SHALL EMPLOY A PUMP AND HAUL METHOD TO BYPASS SECTIONS OF GRAVITY SEWER MAIN UNDER CONSTRUCTION. CONTRACTOR SHALL PUMP WASTE FROM A MANHOLE UPSTREAM OF THE CONSTRUCTION INTO A TANKER TRUCK AND REINTRODUCE THE WASTE BACK INTO THE SAME SYSTEM AT A MANHOLE DOWNSTREAM OF THE CONSTRUCTION. CONTRACTOR SHALL COORDINATE ALL ASPECTS OF THIS OPERATION WITH THE UTILITY OWNER PRIOR TO BEGINNING ANY SAID WORK. ALL TRANSPORTING OF WASTEWATER SHALL BE IN ACCORDANCE WITH THE RULES AND REGULATIONS OF NCDOT, THE LOCAL MUNICIPALITY, AND OTHER AGENCIES WITH JURISDICTION. CONTRACTOR IS RESPONSIBLE FOR OBTAINING ALL REQUIRED PERMITS ASSOCIATED WITH THE PROPOSED PUMP AND HAUL OPERATIONS.
10. ALL GRAVITY SEWER LINE TO BE D.I. (DUCTILE IRON) PIPE.

ITEM NUMBER	SECTION	DESCRIPTION	QUANTITY	UNIT
2830000000-N	858	ADJUSTMENT OF MANHOLES	20	EA
2845000000-N	858	ADJUSTMENT OF METER BOXES OR VALVE BOXES	19	EA
5325600000-E	1510	6" WATER LINE	1440	LF
5325800000-E	1510	8" WATER LINE	960	LF
5326200000-E	1510	12" WATER LINE	7580	LF
5329000000-E	SP	DUCTILE IRON WATER PIPE FITTINGS	9950	LBS
5540000000-E	1515	6" VALVE	25	EA
5546000000-E	1515	8" VALVE	14	EA
5558000000-E	1515	12" VALVE	31	EA
5648000000-N	1515	RELOCATE WATER METER	15	EA
5649000000-N	1515	RECONNECT WATER METER	45	EA
5666000000-E	1515	FIRE HYDRANT	13	EA
5672000000-N	1515	RELOCATE FIRE HYDRANT	1	EA
5691300000-E	1520	6" SANITARY GRAVITY SEWER	160	LF
5774000000-E	1525	4' DIA UTILITY MANHOLE	2	EA
5798000000-E	1530	ABANDON 2" UTILITY PIPE	1211	LF
5800000000-E	1530	ABANDON 6" UTILITY PIPE	316	LF
5801000000-E	1530	ABANDON 8" UTILITY PIPE	1032	LF
5804000000-E	1530	ABANDON 12" UTILITY PIPE	6963	LF
5815500000-N	1530	REMOVE FIRE HYDRANT	9	EA
5816000000-N	1530	ABANDON UTILITY MANHOLE	1	EA

UTILITY CONSTRUCTION