


This electronic collection of documents is provided for the convenience of the user and is Not a Certified Document –


The documents contained herein were originally issued and sealed by the individuals whose names and license numbers appear on each page, on the dates appearing with their signature on that page.


This file or an individual page shall not be considered a certified document.











PROJECT NO.: 39049.1.1 (U-4405)

CUMBERLAND COUNTY

STATION: MSE RETAINING WALLS NO. 1 & 2

SHEET 5 OF 7

Prepared in the Office of:

Consulting Engineers and Scientists

2401 BRENTWOOD ROAD, SUITE 107

RALEIGH, NORTH CAROLINA 27604

NC REGISTERED ENGINEERING FIRM: F-0869

NC REGISTERED GEOLOGIC FIRM: C-367




NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION
DIVISION OF HIGHWAYS


GEOTECHNICAL ENGINEERING UNIT MSE RETAINING WALLS NO. 1 AND 2 TYPICAL SECTION WITH STEEL BEAM GUARDRAIL

REVISIONS									
. BY	DATE	NO.	BY	DATE	SHEET NO.				
		3			W-5				
		4			V V-5				

PREPARED BY: ALEXANDER, M. J. DATE: 4/4/18

REVIEWED BY: NASH, A. A. DATE: 4/5/18





NOTES:

FOR MECHANICALLY STABILIZED EARTH (MSE) RETAINING WALLS, SEE MECHANICALLY STABILIZED EARTH RETAINING WALLS SPECIAL PROVISION.

FOR TYPE III REINFORCED BRIDGE APPROACH FILL, SEE BRIDGE APPROACH FILLS PROVISION AND ROADWAY DETAIL DRAWING NO. 422D10.

- FOR STEEL BEAM GUARDRAIL, SEE ROADWAY PLANS AND SECTION 862 OF THE STANDARD SPECIFICATIONS.
- AT THE CONTRACTOR'S OPTION, USE FINE AGGREGATE IN THE REINFORCED ZONE OF MSE RETAINING WALLS NO.1 AND 2.
- A SEPARATION GEOTEXTILE IS REQUIRED AT THE BACK OF THE REINFORCED ZONE FOR RETAINING WALLS NO.1 AND 2.
- A DRAIN IS REQUIRED FOR RETAINING WALLS NO. 1 AND 2.

BEFORE BEGINNING MSE WALL DESIGN FOR RETAINING WALLS NO.1 AND 2, SURVEY WALL LOCATION AND SUBMIT A REVISED WALL PROFILE VIEW (WALL ENVELOPE) FOR REVIEW. DO NOT START WALL DESIGN OR CONSTRUCTION UNTIL THE REVISED WALL ENVELOPE IS ACCEPTED.

DESIGN RETAINING WALLS NO. 1 AND 2 FOR THE FOLLOWING:

1) H = DESIGN HEIGHT + EMBEDMENT 2) DESIGN LIFE = 100 YEARS

MATERIAL REQUIREMENTS.

3) MAXIMUM FACTORED VERTICAL PRESSURE ON FOUNDATION MATERIAL = 6,283 PSF (RW1) AND 6,475 PSF (RW2)

4) MINIMUM REINFORCEMENT LENGTH (L) = 0.8H OR 6 FT, WHICHEVER IS LONGER

6) REINFORCED ZONE AGGREGATE PARAMETERS:

AGGREGATE TYPE*	UNIT WEIGHT (γ) PCF	FRICTION ANGLE (φ) Degrees	COHESION (c) PSF
COARSE	110	38	0
FINE	115	34	0
*SEE MSE RETAINING WA	ALLS PROVISION FO	DR COARSE AND FINE A	GGREGATE

7) IN-SITU ASSUMED MATERIAL PARAMETERS:

MATERIAL TYPE	UNIT WEIGHT	FRICTION ANGLE	COHESION
	(γ) PCF	(φ) DEGREES	(c) PSF
BACKFILL	120	30	0
FOUNDATION	110	16	1500

DESIGN RETAINING WALLS NO.1 AND 2 FOR A LIVE LOAD (TRAFFIC) SURCHARGE.

DESIGN RETAINING WALL NO.1 FOR A FACTORED LATERAL LOAD FROM FOUNDATIONS OF THE SOUND BARRIER WALL LOCATED BEHIND THE RETAINING WALL APPLIED AS A FACTORED UNIFORM PRESSURE TO THE BACK OF MSE RETAINING WALL PANELS.


SOUND BARRIER WALL FOUNDATION SPACING	FACTORED LATERAL LOAD BEHIND RETAINING WALL NO.1 (PSF)
10 FT.	320 PSF
15 FT.	420 PSF

DESIGN REINFORCEMENT CONNECTED TO END BENT CAPS FOR THE FACTORED LOAD AND LENGTH OF REINFORCEMENT IN ACTIVE ZONE (L_d) SHOWN. CAST REINFORCEMENT OR CONNECTORS INTO CAP BACKWALL FOR END BENTS NO.1 AND 2 LOCATED AT STATION 26+35.80 -RPB- AND STATION 27+20.21 -RPB-, RESPECTIVELY. MAINTAIN A CLEARANCE OF AT LEAST 3"
BETWEEN REINFORCEMENT OR CONNECTORS AND REINFORCING STEEL IN CAP.

FOUNDATIONS FOR SOUND BARRIER WALLS WILL BE LOCATED BEHIND RETAINING WALL NO.1 AND WILL INTERFERE WITH REINFORCEMENT. BEFORE BEGINNING MSE WALL CONSTRUCTION, SUBMIT PROPOSED CONSTRUCTION METHODS FOR THESE FOUNDATIONS FOR APPROVAL.

FOUNDATIONS FOR END BENTS NO.1 AND 2 LOCATED AT STATION 26+35.80 -RPB- AND STATION 27+20.21 -RPB-, RESPECTIVELY, WILL INTERFERE WITH REINFORCEMENT FOR RETAINING WALLS NO.1 AND 2. SEE "FOUNDATION LAYOUT" SHEET FOR FOUNDATION LOCATIONS.

DO NOT PLACE LEVELING PAD CONCRETE, AGGREGATE OR REINFORCEMENT FOR RETAINING WALLS NO.1 AND 2 UNTIL EXCAVATION DIMENSIONS AND FOUNDATION MATERIAL ARE APPROVED. AT THE CONTRACTOR'S OPTION, "TEMPORARY SHORING FOR WALL CONSTRUCTION" MAY BE USED TO CONSTRUCT RETAINING WALLS NO.1 AND 2. SEE MSE RETAINING WALLS PROVISION FOR TEMPORARY SHORING FOR WALL CONSTRUCTION.



PRECAST PANELS LEVELING PAD STEP DETAIL

PROJECT NO.: 39049.1.1 (U-4405)

SHEET 7 OF 7


CUMBERLAND COUNTY

STATION: MSE RETAINING WALLS NO. 1 & 2

Prepared in the Office of: **Consulting Engineers and Scientists** 2401 BRENTWOOD ROAD, SUITE 107 RALEIGH, NORTH CAROLINA 27604

NC REGISTERED ENGINEERING FIRM: F-0869

NC REGISTERED GEOLOGIC FIRM: C-367




DIVISION OF HIGHWAYS


NORTH CAROLINA

GEOTECHNICAL ENGINEERING UNIT MSE RETAINING WALLS NO. 1 AND 2 NOTES AND DETAILS


REVISIONS									
NO.	BY	DATE	NO.	BY	DATE	SHEET NO.	İ		
1			3			W-7	İ		
2			4			V V-7	İ		

DATE: 4/18/18 PREPARED BY: ALEXANDER, M. J. REVIEWED BY: NASH, A. A. DATE: 4/18/18





STANDARD SEGMENTAL GRAVITY WALL - PARTIAL ELEVATION



STANDARD SEGMENTAL GRAVITY WALL WITH SLOPE

*SEE ROADWAY PLANS FOR FINISHED GRADE DETAILS.

NOTES:

FOR STANDARD SEGMENTAL GRAVITY RETAINING WALLS, SEE SECTION 454 OF THE STANDARD SPECIFICATIONS.

FOR STEEL BEAM GUARDRAIL, SEE ROADWAY PLANS AND SECTION 862 OF THE STANDARD SPECIFICATIONS.

DO NOT ATTACH FENCES OR HANDRAILS TO STANDARD SEGMENTAL GRAVITY WALLS.

DO NOT USE STANDARD SEGMENTAL GRAVITY WALLS FOR INTERSTATE HIGHWAY OR RAILROAD PROJECTS.

DO NOT USE STANDARD SEGMENTAL GRAVITY WALLS WHEN SURCHARGE LOADS WILL BE WITHIN 5'-6" OF THE BACK OF SRW CAP UNITS.

DO NOT USE STANDARD SEGMENTAL GRAVITY WALLS WHEN VERY LOOSE OR SOFT SOIL OR MUCK IS BELOW WALLS.

SEGMENTAL RETAINING WALL (SRW) UNITS ARE APPROVED FOR EITHER 2'OR 4' MAXIMUM DESIGN HEIGHTS. FOR DETAILS AND DIMENSIONS OF APPROVED SRW UNITS AND MAXIMUM DESIGN HEIGHTS, SEE


connect.ncdot.gov/resources/Geological/Pages/Products.aspx

DO NOT MIX APPROVED SRW UNITS FROM DIFFERENT VENDORS ON THE SAME STANDARD SEGMENTAL GRAVITY WALL. USE THE SAME SIZE APPROVED SRW UNITS FOR EACH WALL

BEFORE BEGINNING STANDARD SEGMENTAL GRAVITY WALL CONSTRUCTION, SURVEY WALL LOCATIONS AND SUBMIT WALL PROFILE VIEWS (WALL ENVELOPES) FOR REVIEW. FOR WALL ENVELOPES, INCLUDE BOTTOM OF WALL, EXISTING GROUND AND GRADE ELEVATIONS AND OTHER ELEVATIONS AS NEEDED AT INTERVALS OF 25'OR LESS ALONG WALLS. DO NOT START WALL CONSTRUCTION UNTIL WALL ENVELOPES ARE ACCEPTED.

A DRAIN PIPE IS REQUIRED IF GROUNDWATER IS ABOVE BOTTOM OF FOOTINGS.

DO NOT PLACE NO.57 STONE FOR FOOTINGS UNTIL EXCAVATION DIMENSIONS AND FOUNDATION MATERIAL ARE APPROVED.



STANDARD SEGMENTAL GRAVITY WALL WITHOUT SLOPE

*SEE ROADWAY PLANS FOR FINISHED GRADE DETAILS.

PROJECT NO.: 39049.1.1 (U-4405)

CUMBERLAND COUNTY

GEOTECHNICAL ENGINEER

040231

Matt llexander 4/30/2018

DOCUMENT NOT CONSIDERED FINAL

UNLESS ALL SIGNATURES COMPLETED

STATION: 258+12.91 -L-

SHEET 2 OF 2

STANDARD DETAIL NO. 454.01

STANDARD **SEGMENTAL GRAVITY RETAINING WALL**

DATE: 1-16-18


GEOTECHNICAL ENGINEERING UNIT

NORTH CAROLINA

DEPARTMENT OF TRANSPORTATION

DIVISION OF HIGHWAYS


SHEET NO. W-9



CONCRETE PILE —

TO 15° TURNS

· 3'-0"Ø HOLE FOR PILE EXCAVATION



NOTES

FOR SOUND BARRIER WALL, SEE GEOTECHNICAL SPECIAL PROVISIONS.

CONSTRUCT SOUND BARRIER WALL TO LINES AND GRADES SHOWN ON THE ROADWAY PLANS.

PROVIDE PANELS WITH A FLAT BOTTOM.

VERIFY THE LOCATION OF UNDERGROUND UTILITIES BEFORE DRILLING HOLES TO ENSURE SUFFICIENT CLEARANCE IS AVAILABLE.

ADJUST PILE EXCAVATION ELEVATIONS TO MAINTAIN 6"MINIMUM EMBEDMENT OF THE BOTTOM PANEL.

USE CLASS AA FOR PANELS AND CLASS A CONCRETE PILE EXCAVATION BACKFILL, IN ACCORDANCE WITH ARTICLE 1000-4 OF THE STANDARD SPECIFICATIONS.

AT THE CONTRACTOR'S OPTION, USE 10'-0", 15'-0", OR 20'-0" PILE SPACINGS. STANDARD PRECAST CONCRETE PANELS MAY BE USED WITH THE 10'-0" AND 15'-0" PILE SPACING. FOR 20'-0" PILE SPACING, PANELS DESIGNED AND MANUFACTURED BY A THIRD PARTY VENDER SHALL BE USED.

FOR SOUND BARRIER WALL STATIONS, OFFSETS, AND WALL ENVELOPE, SEE ROADWAY PLANS.

PLACE 1" Ø BACKER RODS FULL HEIGHT ON EACH SIDE OF THE PRECAST PANELS. SET AND SEAL THE BACKER ROD IN PLACE WITH SEALANT THAT CONFORMS WITH ARTICLE 1028-3 OF THE STANDARD SPECIFICATIONS.


FOR SUBMITTAL OF WORKING DRAWINGS, SEE SPECIAL PROVISIONS.

FOR FALSEWORK AND FORMWORK, SEE SPECIAL PROVISIONS.

PILE EXCAVATION DEPTHS ARE BASED ON 36-INCH DIAMETER HOLES. FOR 30-INCH DIAMETER HOLES, ADD 1 FOOT TO THE PILE EXCAVATION DEPTHS SHOWN.

SOUND BARRIER WALL 1 PILE LOCATIONS SHALL BE SLEEVED DURING CONSTRUCTION OF MSE RETAINING WALL 1. SLEEVES FOR SOUND BARRIER WALL FOUNDATIONS SHALL BE CONSIDERED INCIDENTAL TO MSE RETAINING WALL 1. SEE MSE WALL PLANS AND GEOTECHNICAL SPECIAL PROVISIONS.

	PILE REINFORCING STEEL design wind pressure = 40 psf										
	PILE ⁻	TYPE I			PILE T	PE III					
PILE SPACING	MAXIMUM WALL HEIGHT (H)	VERTICAL REINFORCING STEEL	TIES	PILE SPACING	MAXIMUM WALL HEIGHT (H)	VERTICAL REINFORCING STEEL	TIES				
10'-0"	H ≤ 25′	4 - *8 EA.FACE	#3 @ 1'-4"CTS.	10'-0"	H ≤ 25′	3 - #9 SHORT FACE 4 - #9 LONG FACE	*3 @ 1'-4"CTS.				
15/ 0//	H ≤ 20′	4 - #8 EA.FACE	#3 @ 1'-4"CTS.	15/ 0#	H ≤ 20′	3 - #9 SHORT FACE 4 - #9 LONG FACE	#3 @ 1'-4" CTS.				
15'-0"	20'< H ≤ 25'	4 - *10 EA.FACE	#3 @ 1'-4"CTS.	15'-0"	20'< H ≤ 25'	3 - *11 SHORT FACE 4 - *11 LONG FACE	#3 @ 1'-4"CTS.				
20'-0"	H ≤ 20′	4 - #9 EA.FACE	#3 @ 1'-4"CTS.	20′-0″	H ≤ 20′	3 - *10 SHORT FACE	#3 @ 1'-4"CTS.				
20 -0	20′< H ≤ 25′	4 - #11 EA. FACE	#3 @ 1'-4"CTS.	20 -0	H 3 20	4 - *10 LONG FACE	"5 W 1 -4 C13.				
	PILE T	YPE II		PILE TYPE III ALT.							
PILE SPACING	MAXIMUM WALL HEIGHT (H)	VERTICAL REINFORCING STEEL	TIES	PILE SPACING	MAXIMUM WALL HEIGHT (H)	VERTICAL REINFORCING STEEL	TIES				
10'-0"	H ≤ 25′	4 - * 6 EA.FACE	# 3 @ 1′−4″CTS.	10'-0"	H ≤ 25′	3 - #9 SHORT FACE 4 - #9 LONG FACE	*3 @ 1'-4"CTS.				
15/ 0"	H ≤ 20′	4 - #6 EA.FACE	#3 @ 1'-4"CTS.	15', 0"	H ≤ 20′	3 - *9 SHORT FACE 4 - *9 LONG FACE	*3 @ 1'-4"CTS.				
15'-0"	20'< H ≤ 25'	4 - *7 EA.FACE	#3 @ 1'-4"CTS.	15'-0"	20'< H ≤ 25'	3 - *11 SHORT FACE 4 - *11 LONG FACE	#3 @ 1'-4"CTS.				
20'-0"	H ≤ 20′	4 - #6 EA.FACE	#3 @ 1'-4"CTS.	20′-0″	U 100	3 - #10 SHORT FACE	#7 O 1/ A# CTC				
20'-0"	20'< H ≤ 25'	4 - *8 EA.FACE	#3 @ 1'-4"CTS.	20 -0	H ≤ 20′	4 - #10 LONG FACE	#3 @ 1'-4"CTS.				



BILL OF MATERIAL

SOUND BARRIER WALL

ARCHITECTURAL SURFACE TREATMENT

OUANTITIES PROVIDED ARE APPROXIMATE AND ARE FOR BID PURPOSES ONLY.

ARCHITECTURAL SURFACE TREATMENT

ARCHITECTURAL SURFACE TREATMENT

TEXTURE OPTION:

STAIN OPTION:

FS 36270

PROJECT NO. U-4405

CUMBERLAND COUNTY

STATION: 10+00.00 -NW1-

SHEET 1 OF 3

DEPARTMENT OF TRANSPORTATION
RALEIGH

STANDARD

SOUND BARRIER WALL

REVISIONS

DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED 2

SEAL 29441

P. CHOINEER

the Z. W. ayou

PILE ROTATION LIMIT FOR WALL TURN

(ROTATE THE CONCRETE PILE ±7°-30′-00″ TO ACCOMMODATE WALL TURN.)

— CONCRETE SHIM BLOCK

TYPICAL WALL TURN DETAILS

3'-0"Ø HOLE FOR PILE

EXCAVATION

CONCRETE PILE -

REV. 9/26/14 REV. 10/17 REV. 5/18

ASSEMBLED BY : K.W. ALFORD

CHECKED BY : G.W. DICKEY

DRAWN BY : MAA 6/II

CHECKED BY : GM 6/II

15° TO 45° TURNS

(PILE TYPE III)

DATE : 6/18

DATE : 6/18

MAA/TMG

MAA/THC


MAA/THC

DATE:

SHEET NO

SBW-1

TOTAL SHEETS





ASSEMBLED BY : K.W. ALFORD CHECKED BY : G.W. DICKEY


DRAWN BY: MAA 6/II CHECKED BY: GM 6/II

DATE : 6/18 DATE : 6/18


RWW/TMG MAA/THC MAA/THC










QUAI	NTITIE:	S F	OR	ONE	PRI	ECAST	PANE	L (F	OR	15'-C	"PII	_E SP	ACING	;)
PANEL	CLASS AA						[BAR TY	'PES					
HEIGHT	CONCRETE			F	IORIZO	NTAL					VER	RTICAL		
	C.Y.	NO.	BAR	SIZE	TYPE	LENGTH	WEIGHT	(IP) N(). BA	R SIZE	TYPE	LENGTH	WEIGHT	(IP)
3'-0"	0.52	5	H1	#4	STR	13'-8"	46	10	5 V1	#4	STR	2'-8"	29	
4'-0"	0.69	6	H2	#4	STR	13'-8"	55	10	5 V	2 #4	STR	3′-8″	39	
5′-0″	0.86	7	Н3	#4	STR	13'-8"	64	10	5 V.	3 #4	STR	4'-8"	50	
6′-0″	1.04	8	Н4	#4	STR	13′-8″	73	10	5 V	1 #4	STR	5′-8″	61	













(AREA = 1.7163 SQ.FT.)



SECTION THROUGH PRECAST PANELS



PILE DETAIL

(ALL CORNERS TO BE CHAMFERED 1")

(AREA = 1.8336 SQ. FT.)

PROJECT NO. U-4405 CUMBERLAND __ COUNTY STATION:10+00.00 -NW1-

SEAL 29441 PACINET WALLER the I.W. ayout

STANDARD SOUND BARRIER WALL

STATE OF NORTH CAROLINA

DEPARTMENT OF TRANSPORTATION


DETAILS


6/7/2018 SHEET NO **REVISIONS** SBW-2 NO. BY: DATE: DATE: DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED TOTAL SHEETS 3

SHEET 2 OF 3

07-JUN-2018 07:41 A:\Structures\Plans\U4405_SMU_SBW.dgn kalford

STD. NO. SBW2





NOTES

CONCRETE DESIGN DATA : f'c = 5,000 PSI


PROPOSED DEVICES FOR LIFTING PILES, RECESS DETAILS, AND PATCHING MATERIAL SHALL BE DETAILED IN SHOP DRAWINGS.


AFTER ATTACHMENTS HAVE BEEN REMOVED, OPENINGS SHALL BE
REPAIRED SUCH THAT THE APPEARANCE OF THE PILE IS UNIFORM.

WHERE CAST-IN-PLACE LIFTING DEVICES ARE NOT USED, PICK-UP POINTS TO BE INDICATED WITH A BLACK MARK 2"WIDE.

THE SLIP-FORM METHOD OF CASTING PILES WILL NOT BE PERMITTED. ALL CORNERS TO BE CHAMFERED 1".


QUANTITIES FOR ONE PRECAST CONCRETE PILE													
APPROX.	ONE PICK	-UP POINT	TWO PICK-UP POINT										
TONS	0.300L	0.700L	0.207L	0 . 586L									
1 . 56	3'-0''	7′-0′′											
2 . 35	4'-6''	10′-6′′											
3.14	6′-0′′	14'-0''											
3 . 93	7′-6′′	17′-6′′											
4.70	9'-0''	21'-0''											
5 . 49	10'-6''	24'-6''											
6 . 28	12'-0''	28'-0''											
7.05	13'-6''	31′-6′′											
7.84	15'-0''	35′-0′′											
8 . 63			11'-41/2''	32'-3''									
9.42			12'-5''	35'-2''									
	APPROX. PILE WT. TONS 1.56 2.35 3.14 3.93 4.70 5.49 6.28 7.05 7.84 8.63	APPROX. PILE WT. TONS 0.300L 1.56 3'-0" 2.35 4'-6" 3.14 6'-0" 4.70 9'-0" 5.49 10'-6" 7.05 13'-6" 7.84 15'-0" 8.63	APPROX. PILE WT. TONS 0.300L 0.700L 1.56 3'-0'' 7'-0'' 2.35 4'-6'' 10'-6'' 3.14 6'-0'' 17'-6'' 4.70 9'-0'' 5.49 10'-6'' 6.28 12'-0'' 7.05 13'-6'' 13'-6'' 13'-6'' 35'-0'' 8.63	APPROX. PILE WT. TONS 0.300L 0.700L 1.56 3'-0'' 7'-0'' 2.35 4'-6'' 3.14 6'-0'' 14'-0'' 3.93 7'-6'' 4.70 9'-0'' 5.49 10'-6'' 6.28 12'-0'' 7.05 13'-6'' 13'-6'' 13'-6'' 13'-6'' 13'-6'' 11'-4\/2''									





ASSEMBLED BY : K.W. ALFORD CHECKED BY : G.W. DICKEY DATE: 6/18 DATE: 6/18 REV. 1/15/14 REV. 12/17

DRAWN BY: MAA 6/II CHECKED BY: GM 6/II



PILE DETAIL FOR VERTICAL BAR PILE REINFORCING, SEE SHEET 1 OF 3

____ 3-VERT. BARS #3 S7— — 4-VERT. BARS $\frac{1\frac{1}{2}}{CL}$ 1'-6" SEAL 29441 TYPE - III (ALT.) CAGINEER &

PROJECT NO. U-4405 CUMBERLAND COUNTY STATION: 10+00.00 -NW1-

SHEET 3 OF 3

tup 2. W. aford

STATE OF NORTH CAROLINA DEPARTMENT OF TRANSPORTATION
RALEIGH

STANDARD

SOUND BARRIER WALL DETAILS

6/7/2018 SHEET NO **REVISIONS** SBW-3 NO. BY: DATE: DATE: DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED TOTAL SHEETS

STD. NO. SBW3