DocuSign Envelope ID: FC8E86D7-D86A-4F53-BAFD-EC04BB140CC0


INSTALL BOX AS CLOSE * SEE DETAIL DRAWING FOR "CAST IRON METER BOX FOR %" AND 1" METERS". TO R/W AS POSSIBLE EXTEND TAILPIECE R/W TO ROW * STANDARD METER BOX (SEE NOTE 1 FOR LOCATION) 1. DO NOT INSTALL METER BOX METER INSIDE A FENCE OR WITHIN SIDEWALK OR DRIVEWAY. 2. ANGLE VALVES AND YOKE TO BE 3/4" OR 1" -SIZE TO BE DETERMINED BY THE ENGINEER. 3. COPPER PIPE SHALL CONFORM TO THE TECHNICAL SPECIFICATIONS FOR "COPPER PIPE". BRICK COPPER PIPE (SINGLE PIECE) METER— ---- CRIMP YOKE COMPRESSION TO MALE COUPLING 1" BRASS PLUG L_{1" x 1"} BRASS TEE (1" x 1" x 3/4" IS ACCEPTABLE FOR 5/8" METER) SERVICE SADDLE & SERVICE SADDLE &


1" BRASS CORPORATION COCK


(MAX. 30° FROM HORIZONTAL)


1" BALL VALVE CURB STOP

(B84-444-G-NL BY FORD OR B-25122N BY MUELLER) CITY OF WINSTON-SALEM DEPARTMENT OF PUBLIC WORKS ENGINEERING DIVISION N.T.S. REVISED 4-17-2020









Prepared in the Office of:

5438 WADE PARK BOULEVARD, SUITE 200, RALEIGH, NC 27607 919-461-1100 F - 0342

> DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED

PROJECT REFERENCE NO. SHEET NO. U-5824 UC-3A DESIGNED BY: FR DRAWN BY: FR/RR CHECKED BY: SS APPROVED BY: JT EVISED: NORTH CAROLINA DEPARTMENT OF TRANSPORTATION 10/4/2023 | 12:06 PM EDT JTILITIES ENGINEERING SE

UTILITY CONSTRUCTION

PHONE: (919)707-6690

FAX: (919)250-4151

UTILITY CONSTRUCTION

2" Water Main Tap to 6" or Larger Water Main

