

| BILL OF MATERIAL | | | | | | | | | |
|-------------------------------------|-----|------|------|--------|--------|------|--|--|--|
| CONCRETE MEDIAN | | | | | | | | | |
| BAR | NO. | SIZE | TYPE | LENGTH | WEIGHT | | | | |
| 米 B1 | 177 | #4 | STR. | 2'-9" | 325 | | | | |
| ₩ B2 | 21 | #4 | STR. | 33′-4″ | 468 | | | | |
| ₩ B3 | 3 | #4 | STR. | 24'-6" | 49 | | | | |
| ₩ B4 | 3 | #4 | STR. | 26'-7" | , C | 53 | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| * EPOXY COATED REINFORCING STEEL | | | | | | LBS. | | | |
| CLASS AA CONCRETE 15.3 C. | | | | | | | | | |

LUMP SUM PRICE BID FOR THE REINFORCED CONCRETE DECK SLAB.

GROOVED CONTRACTION JOINTS, $\frac{1}{2}$ " in depth, shall be tooled IN ALL EXPOSED FACES OF THE MEDIAN STRIP IN ACCORDANCE WITH ARTICLE 825-10(B) OF THE STANDARD SPECIFICATIONS. THE CONTRACTION JOINTS SHALL BE LOCATED AT A SPACING OF 8 FT. TO 10 FT.BETWEEN EXPANSION JOINTS. NO CONTRACTION JOINTS

THE MEDIAN IN EACH SPAN SHALL NOT BE CAST UNTIL ALL SLAB CONCRETE IN THAT SPAN HAS BEEN CAST AND HAS REACHED A

| | | J | CT NO OHNST(ON: <u>36+</u> | NC | CO | UNTY | | |
|--------------------------|--|--|--|-----|-------|-----------------------|--|--|
| 00 cense No. F-0112 | BYUNGS UP SSION BYUNGS UMPPENSION 1911BA258 SE AL 15825 NCINEER O. KLAPPELIU | | DEPARTMENT OF TRANSPORTATION RALEIGH SUPERSTRUCTURE CONCRETE MEDIAN STRIP DETAILS | | | | | |
| Planners Scientists | 10/4/2021 | REVISIONS SHEET NO NO. BY: DATE: NO. BY: DATE: S-28 | | | | | | |
| NOT CONSID SIGNATURES | ERED FINAL COMPLETED | NO. BY: 1 2 | DATE: NO. 3 | BY: | DATE: | TOTAL SHEETS 54 | | |