1. FITTING JOINTS SHALL NOT BE POURED IN CONCRETE OR HAVE CONCRETE SPILLED ON

THE BOLTS OR NUTS. THE FITTING SHALL BE WRAPPED IN A LAYER OF POLYETHYLENE

2. ROD AND EYE BOLT DIAMETER SHALL BE A MINIMUM OF 34" AND SHALL MATCH

3. CONTRACTOR SHALL REPLACE FITTING BOLTS WITH THREADED ROD FOR 1/2 OF THE BOLTS SUPPLIED WITH EACH FITTING. RODS SHALL BE EQUALLY SPACED.

E THRUST BLOCK (DEADMAN) DETAIL

PLASTIC PRIOR TO POURING THE THRUST BLOCK.

UC-3B NTS

THE SIZE OF THE BOLT PROVIDED WITH THE FITTING.

APPROVED

D GATE VALVE & VALVE BOX INSTALLATION DETAIL

PATENT ANCHOR

CONCRETE BASE

THE DIMENSION

OF THE VALVE

TO BE TWO TIMES

UC-3B NTS

SHEET NO.

UC-3B

Rega M. Schuler

PLANS ONLY

**DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED** 

- CAST IRON (FLANGED END)

FLAP VALVE (SAME SIZE AS PIPELINE)

PROJECT REFERENCE NO.

14SP.20441.1

DESIGNED BY: DRD

CHECKED BY: LAM

NORTH CAROLINA

DEPARTMENT OF

TRANSPORTATION