

MATCHLINE -L- STA. 814+00.00 SEE SHEET 40

MATCHLINE -L2B- STA. 828+00.00 SEE SHEET 42

LEGEND

- 2" ELECTRICAL CONDUIT
- STUB UP LOCATION
- FLUSH MOUNTED PEDESTAL LOCATION

ESTIMATED BILL OF MATERIALS		
UNIT	ITEM	QTY
LF	ELECTRICAL CONDUIT, TYPE BD, SIZE 2"	2820'
EA	FLUSH MOUNTED PEDESTAL	7


PROJECT REFERENCE NO.	SHEET NO.
R-5709C	ECS-1
RW SHEET NO.	

DOCUMENT NOT CONSIDERED FINAL
UNLESS ALL SIGNATURES COMPLETED

DESCRIPTION	ALN	STATION	OFFSET	LOC
LOC 1	-L-	818+00	59'	LT
LOC 2	-L-	819+71	55'	LT
LOC 3	-L-	821+42	55'	LT
LOC 4	-Y26-	11+30	92'	LT
LOC 5	-Y26-	12+27	51'	LT
LOC 6	-Y26-	12+32	38'	RT
LOC 7	-Y26-	10+38	76'	RT
LOC 8	-L-	825+54	40'	LT
LOC 9	-L-	826+18	39'	LT
LOC 10	-L-	825+54	41'	RT
LOC 11	-Y27-	13+03	85'	RT
LOC 12	-Y27-	11+78	31'	RT
LOC 13	-Y27-	11+76	39'	LT
LOC 14	-Y27-	12+72	75'	LT
LOC 15	-L-	822+39	73'	RT
LOC 16	-L-	820+83	68'	RT
LOC 17	-L-	819+14	64'	RT
LOC 18	-L-	817+45	65'	RT
LOC 19	-RAB_L-	11+19	37'	LT
LOC 20	-RAB_L-	11+32	48'	RT
LOC 21	-Y27-	11+19	33'	RT

PROJECT NOTES

- BURY CONDUIT AT MINIMUM DEPTH OF 36".
- INSTALL CONTINUOUS RUN OF CONDUIT BETWEEN POINTS AND STUB UP CONDUIT AT EACH LOCATION AS INDICATED.
- TAPE ENDS OF CONDUIT AT ALL STUB UP LOCATIONS.
- LIGHT POLES AND CONDUCTOR TO BE INSTALLED BY OTHERS AND ARE NOT PART OF THIS PROJECT.
- INSTALL CONDUIT IN AS STRAIGHT OF A RUN AS POSSIBLE BETWEEN STUB UP LOCATIONS.



MATCHLINE -Y26- STA. 14+50.00 SEE SHEET 44

CONDUIT LAYOUT

CONDUIT LOCATIONS FOR
FUTURE DUKE ENERGY LIGHTING

HOKE COUNTY



P: (919) 878-9560
8601 Six Forks Road, Forum 1, Suite 700
Raleigh, North Carolina 27615-3960
NC License No. F-0112

Engineers | Construction Managers | Planners | Scientists

www.rkk.com

Responsive People | Creative Solutions