



---

10600 Nations Ford Road, Suite 150, Charlotte, NC 28273

01/27/2022

Mr. Stephen Wood  
Pipeline Safety Manager  
North Carolina Utilities Commission Department of Commerce  
4325 Mail Service Center  
Raleigh, NC 27699-4325  
[wood@ncuc.net](mailto:wood@ncuc.net)

Re: Pitt Landfill Gas, LLC: Pipeline Abandonment Competition Notice

Mr. Wood -

As of December 31, 2021, Pitt Landfill Gas, LLC ("Pitt"), ceased operations. Our technician did an initial evacuation of the pipeline on 12/31/2021. As of 1/25/2022 all abandoned piping has been disconnected from all sources and supplies of gas. All abandoned and inactive piping has been checked for presence of residual combustible gas, completely purged, and capped.

Service to the hospital has been terminated. All off Pitt's associated piping inside the hospital has been purged and/or removed from service. The gas line coming into the building has sealed.

Our producer for purging started at 10:00 on 1/24/2022 when we opened our bypass line at the landfill to evacuate any gas between the landfill and the hospital. We ran our flare at the landfill all night and checked the line at 08:00 on 1/25/2022 and recorded a reading of 20.1% Oxygen, 0.7% CO2, 0.1% CH4 and 79.1% Balance. The pipeline was sealed on both ends thereafter.

No combustible mixtures are present in any of the related items above and we have officially abandoned the line.

Documentation of these procedures have been entered in the site operations log and a copy sent to the main office.

Please call or email me with any questions. [William.Brinker@landfillgroup.com](mailto:William.Brinker@landfillgroup.com) / 704-844-8990.

Respectfully,

William Brinker  
Managing Director

CC:

Hillary King – NCUC, [hking@ncuc.net](mailto:hking@ncuc.net)

David Kramer – NCDOT, [dpkramer@ncdot.gov](mailto:dpkramer@ncdot.gov)

John Demary – Pitt County Solid Waste, [John.demary@pittcountync.gov](mailto:John.demary@pittcountync.gov)

---