PROJECT REFERENCE NO.	SHEET N
I-5898	Sig 8.

MAXTIME OVERLAP PROGRAMMING DETAIL FOR DEFAULT PHASING

Front Panel

Main Menu >Controller >Overlap >Overlap Parameters/Overlap Timings

Web Interface

Home >Controller >Overlap Configuration >Overlaps

Overlap Plan 1

Overlap	1	3	
Туре	FYA 4 - Section	FYA 4- Section	
Included Phases	2	2	
Modifier Phases	1	÷	
Modifier Overlaps	÷	÷	
Trail Green	0	0	
Trail Yellow	0.0	0.0	
Trail Red	0.0	0.0	

MAXTIME STARTUP AND SOFTWARE FLASH PROGRAMMING DETAIL

Front Panel

Main Menu >Controller >Unit

Web Interface

Home >Controller >Unit

Modify parameters as shown below and save changes.

Start Up Parameters

StartUp Clearance Hold

Unit Flash Parameters

All Red Flash Exit Time

OUTPUT CHANNEL CONFIGURATION

Front Panel

Main Menu >Controller >More>Channels>Channels Config

Web Interface

Home >Controller >Advanced IO>Channels>Channel Configuration

Channel Configuration

Channel	Control Type	Control Source	Flash Yellow	Flash Red	Flash Alt	MMU Channel
1	Phase Vehicle	1		Х	Х	1
2	Phase Vehicle	2		Х		2
3	Phase Vehicle	3		Х	Х	3
4	Phase Vehicle	4		Х		4
5	Phase Vehicle	5		Х		5
6	Phase Vehicle	6		Х	Х	6
7	Phase Vehicle	7		Х		7
8	Phase Vehicle	8		X	Х	8
9	Overlap	1		Х	X	9
10	Overlap	2		Х	Х	10
11	Overlap	3		Х		11
12	Overlap	4		X		12
13	Phase Ped	2				13
14	Phase Ped	4				14
15	Phase Ped	6				15
16	Phase Ped	8				16
17	Overlap	5		X	Х	17
18	Overlap	6		Х		18

THIS ELECTRICAL DETAIL IS FOR THE SIGNAL DESIGN: 07-1475 T2 DESIGNED: June 2025 SEALED: 6/30/2025 REVISED: N/A

<u> Signal Upgrade - Temp Design 2 (TMP Phase III)</u>

ELECTRICAL AND PROGRAMMING

US 311/NC 135 US 220 Southbound Ramps

Rockingham County PLAN DATE: June 2025 REVIEWED BY: PREPARED BY: Golam Moinuddin REVIEWED BY: REVISIONS INIT. DATE

DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED

Prepared in the Offices of: Johnson, Mirmiran, & Thompson Inc. 4700 Falls of Neuse Rd, Suite 100, Raleigh, NC, 27606