

## Li, Dennis G

---

**To:** Teague, Jeff L; Stroder, Jeffrey A  
**Cc:** Caldwell, Ethan J (ejcaldwell@ncdot.gov); Scholl, William B  
**Subject:** RE: U-5743 Phase II GeoEnvironmental. 65% Plan, right of way plan review comment and recommendation.... No phase II for all/any of the 3 sites of concern in Phase I report dated 2018.

Jeff and Jeff, per your requests, based on my review of the current plan and the Phase I report ( I did in 2018), here is my comment and recommendation. If the plan changes or you find anything concerns you during your field visits and property contact, please let me know, I will review it again. Thank you and have a great day. Dennis

- 1) Site 1 (Parcel 13), active Outdoor equipment repair business, Robert Small property located at 947 Salisbury Street, Asheboro, NC 27203. Only Minimum permanent drainage easement impact, limited earthwork, concerned area at the site is located outside and down gradient to the construction area. No Phase II.
- 2) Site 2 (No Parcel #), out of construction limit. No Phase II.
- 3) Site 3 (Parcel 38), active Auto and Tire business, Ruth Bray property located at 340 NC HWY 42 N, Asheboro, NC 27203. Only Minimum construction easement impact, limited earthwork, no Phase II.

**Dennis G. LI, Ph.D., LG,**  
GeoEnvironmental Project Engineer  
North Carolina Department of Transportation

919 707 6857 office  
919 999 3991 mobile  
[dgli@ncdot.gov](mailto:dgli@ncdot.gov)

1020 Birch Ridge Drive  
Raleigh, NC 27610  
1589 Mail Service Center  
Raleigh, NC 27699-1589

