

Huff, Christy

From: Upole, Larry L
Sent: Saturday, January 19, 2013 7:44 PM
To: Huff, Christy; Mabry, Virginia G
Subject: FW: Lake Waccamaw bridge #342

fyi

From: Garrell, Nicky L
Sent: Friday, January 18, 2013 8:47 AM
To: Upole, Larry L
Cc: Godwin, Arthur M; Donny Joyce (donny.joyce@pomonapipelineproducts.com); Pittman, Darren K; Griffin, Michael D
Subject: Lake Waccamaw bridge #342

Sonny, spoke with Dean Nealy with Progress about the power line. It cannot be back fed. To relocate, our options would be directional bore, extend over with cross arms (about 6') or raise the poles higher. Buddy talked to the town about the sewer lines at the bridge. The biggest one is abandoned the one beside it is forced sewer. I think the one on the other side is water. Hope this helps.

Nick

Email correspondence to and from this sender is subject to the N.C. Public Records Law and may be disclosed to third parties.