

PROJ. NO. - 6.469002T

ID NO. - R-0513BB

COUNTY - ROBESON

B1-A

SOIL TEST RESULTS														
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE
							C.SAND	F.SAND	SILT	CLAY	10	40	200	
SS-06	26.0 LT	14+02.1	0.00-0.45	A-4(3)	23	10	18.3	24.7	31.9	25.1	100	87	63	11
SS-07	26.0 LT	14+02.1	1.50-1.95	A-7-6(11)	43	23	23.1	20.9	18.2	37.8	99	84	60	21
SS-08	26.0 LT	14+02.1	7.50-7.95	A-3(0)	27	NP	3.4	89.7	2.8	4.1	99	98	9	38
SS-31	26.0 LT	14+02.1	9.00-9.45	A-1-b(0)	32	NP	81.4	10.2	4.0	4.4	83	35	9	26
SS-09	26.0 LT	14+02.1	12.00-12.45	A-6(13)	38	19	7.1	24.5	40.0	28.4	100	96	74	20
SS-10	26.0 LT	14+02.1	16.50-16.95	A-7-5(46)	70	39	0.6	2.4	15.2	81.8	100	100	98	39

E1-C

SOIL TEST RESULTS														
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE
							C.SAND	F.SAND	SILT	CLAY	10	40	200	
SS-144	CL	13+88.4	0.89-1.34	A-7-6(23)	56	38	18.1	18.3	23.0	40.6	100	88	66	-
SS-145	CL	13+88.4	2.41-2.86	A-7-6(13)	51	33	4.7	47.1	9.6	38.6	100	97	53	-
SS-146	CL	13+88.4	3.93-4.38	A-2-4(0)	27	NP	0.4	80.4	5.0	14.2	100	100	31	-
SS-147	CL	13+88.4	6.97-7.42	A-2-4(0)	27	NP	1.2	90.8	6.0	2.0	100	99	12	-
SS-148	CL	13+88.4	10.01-10.46	A-2-6(0)	35	16	59.5	20.9	7.4	12.2	98	66	21	-
SS-149	CL	13+88.4	11.53-11.98	A-2-4(0)	28	10	19.7	53.4	10.7	16.2	100	91	32	-
SS-150	CL	13+88.4	13.05-13.50	A-2-4(0)	23	NP	38.8	52.2	2.9	6.1	100	84	11	-
SS-151	CL	13+88.4	14.57-15.02	A-7-6(29)	54	32	7.3	12.6	31.4	48.7	100	96	85	28
SS-152	CL	13+88.4	17.61-18.06	A-7-5(50)	76	41	1.0	2.0	13.7	83.2	100	99	98	-
SS-153	CL	13+88.4	22.17-22.22	A-2-4(0)	21	NP	59.5	30.1	2.3	8.1	97	64	11	-