

SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L.I.	% BY WEIGHT				% PASSING SIEVES			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS 110	0.0	40+00.0	0.80-1.25	A-2-6(1)	37	14	18.5	50.4	1.8	29.3	93.4	88.3	35.2	27	NS
SS 111	0.0	40+00.0	2.60-3.05	A-2-4(0)	22	NP	40.7	45.9	3.4	10.0	100.0	86.7	14.2	26	NS
SS 112	0.0	43+00.0	1.50-1.95	A-2-5(0)	43	5	20.9	47.4	4.6	27.1	100.0	92.9	33.1	19	NS
SS 113	0.0	46+00.0	0.00-0.45	A-2-4(0)	24	NP	21.7	52.9	6.9	18.5	99.9	94.4	27.2	14	NS
SS 114	0.0	46+00.0	0.80-1.25	A-7-5(2)	43	11	19.7	40.6	2.9	36.8	96.4	92.2	41.1	21	NS
SS 115	0.0	46+00.0	2.60-3.05	A-2-6(0)	30	11	39.5	32.1	9.1	19.3	97.8	87.6	28.7	15	NS

DESCRIPTION:
US 74 FROM SR 1003 TO I-95

PREPARED BY:
CAELIN
ENGINEERS and SCIENTISTS
WILMINGTON, NORTH CAROLINA

DATE: 06/00

5m 0 10m

CONST. REV. _____

R/W REV. _____

PROJECT NO.: 6.469002T SHEET NO. 118

TIP NO.: R-0519C


COUNTY: ROBESON

ROADWAY DESIGN ENGINEER HYDRAULICS ENGINEER


PRELIMINARY PLANS
DO NOT USE FOR CONSTRUCTION

INCOMPLETE PLANS
DO NOT USE FOR R/W ACQUISITION

TGS
ADAPTED FROM:
TGS ENGINEERS
975 WALNUT STREET
CARY, NC 27511
PH (919) 319-8850



-Y8-



-Y8-

Prof. B. DGN