

SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L.I.	% BY WEIGHT				% PASSING SIEVES			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS 49	0.0	5+00	0.80-1.25	A-6(4)	36	23	17.2	44.5	7.1	31.2	99.7	93.1	39.2	22	NS
SS 50	0.0	5+00	1.50-1.95	A-3(0)	21	NP	19.4	70.9	2.7	7.0	100.0	95.3	10.3	22	NS
SS 51	0.0	5+00	4.10-4.55	A-4(0)	26	NP	4.8	14.3	64.8	16.1	100.0	99.1	81.9	32	NS
SS 52	0.0	5+00	8.60-9.05	A-1-b(0)	23	NP	93.8	4.6	0.8	0.8	99.7	21.1	1.8	15	NS
SS 53	0.0	5+00	16.30-16.75	A-6(3)	40	26	54.8	10.5	4.3	30.4	98.6	70.4	35.6	19	NS
SS 54	0.0	5+00	19.30-19.75	A-1-b(0)	30	NP	88.1	5.9	0.0	6.0	97.4	24.9	6.5	25	NS
SS 55	0.0	5+00	20.80-21.25	A-7-6(25)	48	30	2.2	18.6	30.2	49.0	99.7	98.4	83.3	20	NS

DESCRIPTION:

US 74 FROM SR1003 TO I-95




PROJECT NO.: G. 469002T	SHEET NO. 103
TIP NO.: R-0513C	
COUNTY: ROBESON	
ROADWAY DESIGN ENGINEER	HYDRAULICS ENGINEER
PRELIMINARY PLANS DO NOT USE FOR CONSTRUCTION INCOMPLETE PLANS DO NOT USE FOR R/W ACQUISITION	

PREPARED BY:



ENGINEERS and SCIENTISTS
WILMINGTON, NORTH CAROLINA


DATE: 0600



CONST. REV. _____

R/W REV. _____

TGS
ADAPTED FROM:
TGS ENGINEERS
975 WALNUT STREET
CARY, NC 27511
PH (919) 319-8850



Proj03.DGN