


SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L.	% BY WEIGHT				% PASSING SIEVES			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS 79	22.2 Rt	0+30.6	2.60-3.05	A-2-4(0)	24	NP	23.7	56.7	2.3	17.3	97.5	90.9	20.5	25	NS
SS 80	22.2 Rt	0+30.6	4.10-4.55	A-3(0)	25	NP	5.2	88.4	1.6	4.8	95.6	95.5	7.9	27	NS
SS 81	22.2 Rt	0+30.6	8.60-9.05	A-3(0)	28	NP	4.3	87.6	2.2	5.9	96.5	96.3	9.4	14	NS
SS 82	22.2 Rt	0+30.6	11.70-12.15	A-2-6(0)	34	15	25.7	60.4	1.8	12.1	95.7	44.3	14.5	16	NS
SS 83	22.2 Rt	0+30.6	13.20-13.65	A-7-6(9)	41	23	32.2	21.3	15.5	31.0	87.8	72.7	52.7	21	NS
SS 84	22.2 Rt	0+30.6	16.20-16.65	A-1-6(0)	30	NP	79.5	18.3	1.6	0.6	94.2	46.6	4.7	18	NS
SS 85	22.2 Rt	0+30.6	18.55-19.00	A-2-4(0)	27	5	59.7	33.6	2.7	4.0	91.5	62.1	10.3	26	NS
B-26-2	17.4 Rt	2+50.9	0.80-1.25		42	27	SAMPLE ANALYZED FOR L.L. and P.L. ONLY				15				


DESCRIPTION:
US 74 FROM SR1003 TO I-95
 PREPARED BY:
CALIN
 ENGINEERS and SCIENTISTS
 WILMINGTON, NORTH CAROLINA
 DATE: 06/00



PROJECT NO.: 6.469002T SHEET NO. 96
 TIP NO.: R-0513C
 COUNTY: ROBESON
 ROADWAY DESIGN ENGINEER: _____
 HYDRAULICS ENGINEER: _____

PRELIMINARY PLANS
 DO NOT USE FOR CONSTRUCTION
INCOMPLETE PLANS
 DO NOT USE FOR R/W ACQUISITION

TGS ENGINEERS
 ADAPTED FROM:
 TGS ENGINEERS
 975 WALNUT STREET
 CARY, NC 27511
 PH (919) 319-8850



-LPC- @ -Y2-

-LPC- @ -Y2-

Pro096.DGN