


SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L.	% BY WEIGHT				% PASSING SIEVES			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS 39	23.4 Lt	0+51.2	1.50-1.95	A-7-6(13)	54	33	2.3	48.8	10.5	38.4	100.0	99.5	52.0	23	NS
SS 40	23.4 Lt	0+51.2	5.60-6.05	A-3(0)	23	NP	26.9	65.1	0.0	8.0	99.9	88.2	9.3	23	NS
SS 41	23.4 Lt	0+51.2	13.20-13.65	A-2-6(0)	33	14	70.5	15.1	0.4	14.0	91.0	37.4	17.3	15	NS
SS 42	23.4 Lt	0+51.2	16.20-16.65	A-2-6(1)	31	13	53.9	15.1	10.4	20.6	99.6	82.2	32.3	17	NS
SS 43	23.4 Lt	0+51.2	19.30-19.75	A-7-6(20)	51	22	5.5	15.8	30.8	47.9	99.2	96.4	82.0	17	NS

DESCRIPTION:
US 74 FROM SR1003 TO I-95




PROJECT NO.: G. 469002T SHEET NO. 87
 TIP NO.: R-0513C
 COUNTY: ROBESON
 ROADWAY DESIGN ENGINEER
 HYDRAULICS ENGINEER
PRELIMINARY PLANS
 DO NOT USE FOR CONSTRUCTION
INCOMPLETE PLANS
 DO NOT USE FOR R/W ACQUISITION

PREPARED BY:
CALIN
 ENGINEERS and SCIENTISTS
 WILMINGTON, NORTH CAROLINA
 DATE: 06/00

CONST. REV. _____
 RW REV. _____

TGS
 ADAPTED FROM:
 TGS ENGINEERS
 975 WALNUT STREET
 CARY, NC 27511
 PH (919) 319-8850



-RPC- @ -Y2-

Pr0087.DGN