

SOIL TEST RESULTS

SAMPLE NUMBER	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	PL. I.	% BY WEIGHT			% PASSING SIEVES			% MOISTURE	% ORGANIC	
							C. SAND	F. SAND	SILT	CLAY	10	40			200
SS-27	2m Lt.	30+20	0.0 - 0.45	A-4(0)	33	NP	8.1	19.1	43.0	29.8	100	95	77	9	NA
SS-28	2m Lt.	30+20	1.1 - 1.55	A-2-7(5)	62	42	23.2	53.8	4.2	18.8	100	87	30	23	NA
SS-29	2m Lt.	30+20	2.7 - 3.15	A-2-4(0)	24	NP	1.2	86.7	0.6	11.5	100	100	14	26	NA
SS-30	2m Lt.	30+20	4.4 - 4.85	A-2-4(0)	21	NP	56.7	28.4	2.4	12.5	100	55	16	34	NA

DESCRIPTION:
US 74 From West of SR 1157
(Henry Berry Rd.) to West of
SR 1164 (Back Swamp Rd.)




PROJ. NO.: 6.469002T SHEET NO. 55
T.I.P. NO.: R-0513BB TOTAL SHEETS: 65
F.A. NO.: N/A RW SHEET NO.:
COUNTY: Robeson

PREPARED BY:

CAULIN

ENGINEERS and SCIENTISTS
WILMINGTON, NORTH CAROLINA



CONST. REV.

R/W REV.

ROADWAY DESIGN ENGINEER

HYDRAULICS ENGINEER

PRELIMINARY PLANS
DO NOT USE FOR CONSTRUCTION
INCOMPLETE PLANS
DO NOT USE FOR R/W ACQUISITION

