SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	PL. I.	% BY WEIGHT C. SAND	F. SAND	SILT	CLAY	% PASSING SIEVES 10	40	200	% MOISTURE	% ORGANIC
SS-30	CL	46+00	1.02-1.47	A-4(1)	32	10	32.4	28.3	13.2	26.1	99	80	44	-	-

PROJECT REFERENCE NO.	SHEET NO.
R-2568B	X-31

0 2.5 5

METRIC

SS-30
46+00.00 -L-
10.00 LT.
RESIDUAL
TAN STIFF MOIST MIC. CLAYEY SANDY SILT
SOFT WEATHERED ROCK
(TAN HARD DRY CLAYEY SANDY SILT)
DRY
(1/01)
NR
NR
46+00.000
WIDENED SHOULDER
RESIDUAL
ALLUVIUM
+90 - GR WARRANT
45+80.00 -L-
CL
TAN MED. DENSE TO DENSE MOIST MIC. SILTY CSE. SAND
SOFT WEATHERED ROCK
(TAN V. DENSE DRY MIC. SILTY CSE. SAND)
HARD ROCK
DRY
(1/01)
NR
45+80.000
45+60.00 -L-
20.00 LT.
TAN MED. DENSE TO DENSE MOIST MIC. SILTY CSE. SAND
SOFT TO HARD WEATHERED ROCK
(TAN V. DENSE DRY MIC. SILTY CSE. SAND)
HARD ROCK
AR
DRY
(1/01)
45+60.000
45+60.00 -L-
20.00 RT.
+50.00 - BEG GR
45+40.00 -L-
CL
SOFT WEATHERED ROCK
(TAN V. DENSE DRY MIC. SILTY CSE. SAND
TO GRAY HARD DRY CLAYEY F. SANDY SILT)
HARD ROCK
AR
DRY
(1/01)
45+40.000
8% DRVE