



CONST. REV.
R / W REV.

PRELIMINARY PLANS
DO NOT USE FOR CONSTRUCTION
INCOMPLETE PLANS
DO NOT USE FOR R/W ACQUISITION

SOIL SAMPLE TEST RESULTS															
SAMPLE NO.	STATION	OFFSET	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	2.0 mm	425 um	75 um		
SS-16	11+80	CL	0.30-0.45	A-6(8)	37	20	31.0	17.3	21.5	30.2	100	80	56	15	
SS-17	11+80	CL	1.52-1.97	A-1-b(0)	23	NP	74.2	24.7	0.0	1.0	97	47	1		
SS-18	11+80	CL	3.05-3.50	A-4(7)	32	10	3.0	33.4	39.4	24.1	100	98	77		

-SR4-

