

SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS	L.L.	P.I.	% BY WEIGHT		CLAY	% PASSING SIEVES			% MOISTURE	% ORGANIC
							C. SAND	F. SAND		2.00mm	425mm	75mm		
SS-367		13+00 RT (-Y1-)	3.5-5.0	A-6 (6)	39	12	9	39	20	95	92	60		
SS-368		13+00 RT (-Y1-)	8.5-10.0	A-4 (3)	34	NP	14	45	8	91	86	61		
SS-369		13+00 RT (-Y1-)	13.5-15.0	A-4 (5)	31	NP	14	44	8	98	92	60		
SS-370		13+00 RT (-Y1-)	18.5-20.0	A-4 (1)	29	NP	22	43	4	85	75	42		
SS-570		14+10 RT (-Y1-)	0.0-1.5	A-6 (7)	40	13	9	28	21	89	85	61		
SS-571		14+10 RT (-Y1-)	3.5-5.0	A-2-5 (0)	41	5	30	27	16	53	44	26		
SS-572		14+10 RT (-Y1-)	13.5-15.0	A-4 (3)	31	NP	16	48	8	97	90	46		
MS-328		14+10 RT (-Y1-)	3.5-5.0										8.8	
MS-330		14+10 RT (-Y1-)	13.5-15.0										5.7	
SS-371		14+50 RT (-Y1-)	0.0-1.5	A-2-4 (0)	30	6	23	33	22	63	54	33		
SS-372		14+50 RT (-Y1-)	3.5-5.0	A-4 (4)	35	NP	15	43	14	91	84	55		
SS-373		14+50 RT (-Y1-)	8.5-10.0	A-2-4 (0)	34	NP	32	34	10	66	51	30		
SS-374		14+50 RT (-Y1-)	13.5-15.0	A-4 (4)	33	NP	21	45	8	97	86	54		
SS-375		14+50 RT (-Y1-)	18.5-20.0	A-4 (2)	31	NP	20	46	6	96	89	47		
SS-376		14+50 RT (-Y1-)	23.5-25.0	A-4 (3)	29	NP	16	43	8	98	91	51		
SS-377		14+50 RT (-Y1-)	28.5-30.0	A-4 (3)	32	NP	17	42	8	92	84	50		