

ECONOLITE ASC/2S-2100
DUAL-QUAD OPERATION PROGRAMMING
(program controller as shown below)

CONFIGURATION SUBMENU

1. CONTROLLER SEQUENCE	5. TELEMETRY
2. PHASES IN USE	6. TERMINAL PORT
3. PH TO LS ASSIGNMENT	7. ENABLE LOGGING
4. SDLC OPTIONS	8. OPTIONS

PRESS KEYS 1..8 TO SELECT

CONTROLLER SEQUENCE


----- PRIORITY -----

	1	2	3	4	5	6	7	8	9	0	1	2
R1	1	2	3	4	0	0	0	0	0	0	0	0
R2	5	6	7	8	0	0	0	0	0	0	0	0
CG	.	^	.	^

R1,R2 = RING 1 AND RING 2 ASSIGNMENT
CG = BARRIER LOCATION BETWEEN CONCURRENT TIMING GROUPS



END OF SUBMENU

DUAL-QUAD SEQUENCE
RING CONFIGURATION DETAIL



THIS ELECTRICAL DETAIL IS FOR
THE SIGNAL DESIGN: 02-0019
DESIGNED: AUGUST 2004
SEALED: 8/26/04
REVISED:

SIGNAL UPGRADE - SHEET 2 OF 2

	SR 1707 (CHARLES BLVD.) AT SR 1703 (14TH STREET)		
	DIVISION 02 PITT COUNTY GREENVILLE		
	PLAN DATE: AUGUST 2004	REVIEWED BY: <i>R. Henderson</i>	
	PREPARED BY: WILLIAM HAIRSTON	REVIEWED BY:	
REVISIONS	INIT.	DATE	<i>George C. Brown</i> 9/3/04 SIGNATURE DATE
122 N. McDowell St., Raleigh, NC 27603			SIG. INVENTORY NO. 02-0019