

LEGEND
 [X] N60 EQUIVALENT

SOIL TEST RESULTS

SAMPLE NO.	STATION	OFFSET	LINE	DEPTH INTERVAL	AASHTO CLASS.	LL	PI	% PASSING (SIEVES)				% PASSING (SIEVES)			% MOL.	% ORG.
								C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-3	184+07	64 ft LT	-L-	6.0 - 7.5	A-1-b (0)	17	NP	84	13	3	7	99	40	12		
SS-5	184+07	64 ft LT	-L-	13.5 - 15.0	A-1-b (0)	17	NP	22	7	7	2	95	25	10	41.8	
SS-5	184+33	51 ft RT	-L-	13.5 - 15.0	A-7-6 (16)	48	23	5	29	24	42	99	95	70		

