

**RW-1**

<b>SOIL TEST RESULTS</b>															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-36	12M RT	11+70	0.62-1.07	A-2-4(0)	23	9	32.5	41.6	7.7	18.2	100	84	31	-	-
SS-37	12M RT	11+70	1.38-1.83	A-6(3)	34	17	28.9	36.2	6.7	28.3	100	86	40	18.6	-
SS-38	12M RT	11+70	3.66-4.11	A-2-4(0)	19	NP	62.8	27.1	6.1	4.0	99	65	12	-	-
SS-39	12M RT	11+70	5.94-6.39	A-2-7(4)	44	29	39.4	27.9	2.4	30.3	100	78	35	16.6	-

**RW-2**

<b>SOIL TEST RESULTS</b>															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-40	11M RT	12+00	4.40-4.85	A-7-6(28)	61	38	1.6	34.5	15.4	48.5	100	99	74	20.2	-
SS-41	11M RT	12+00	8.20-8.65	A-6(9)	29	15	6.9	26.9	38.0	28.3	100	96	76	19.4	-

**RW-3**

<b>SOIL TEST RESULTS</b>															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-42	10M RT	12+40	2.98-3.43	A-7-6(8)	43	22	10.3	49.1	10.3	30.3	100	95	52	17.8	-
SS-43	10M RT	12+40	5.26-5.71	A-2-6(2)	38	22	37.2	35.2	3.4	24.2	100	86	29	18.5	-
SS-44	10M RT	12+40	6.02-6.47	A-2-6(0)	31	16	76.2	9.5	2.2	12.1	100	51	15	-	-
SS-45	10M RT	12+40	9.06-9.51	A-6(3)	29	18	27.1	34.3	10.3	28.3	100	93	43	23.5	-