

EB1-A

SOIL TEST RESULTS																
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%	
							C.SAND	F.SAND	SILT	CLAY	10	40	200			MOISTURE
SS-1	3.5M LT	12+51.6	0.64-1.09	A-7-6(21)	56	36	8.3	42.4	8.9	40.4	100	95	64	24.0	-	
SS-2	3.5M LT	12+51.6	2.16-2.61	A-7-6(8)	51	32	41.0	20.8	7.9	30.3	98	69	42	-	-	
SS-3	3.5M LT	12+51.6	3.68-4.13	A-2-4(0)	14	NP	35.2	49.7	10.1	5.1	100	84	21	4.8	-	
SS-4	3.5M LT	12+51.6	5.20-5.65	A-6(2)	33	16	29.6	37.6	7.6	25.3	100	87	38	-	-	
SS-5	3.5M LT	12+51.6	5.96-6.41	A-7-6(7)	42	20	16.0	40.8	8.9	34.3	100	93	50	18.0	-	
SS-6	3.5M LT	12+51.6	8.24-8.69	A-2-6(0)	32	14	32.2	46.8	2.8	18.2	100	81	26	8.5	-	
SS-7	3.5M LT	12+51.6	11.28-11.73	A-2-4(0)	24	6	62.2	22.4	3.2	12.1	99	60	16	-	-	
SS-8	3.5M LT	12+51.6	13.05-13.25	A-7-6(26)	45	30	3.0	20.2	36.4	40.4	100	99	86	24.7	-	
SS-9	3.5M LT	12+51.6	15.84-16.29	A-6(9)	40	27	37.0	14.9	19.8	28.3	98	76	50	-	-	
SS-10	3.5MLT	12+51.6	17.36-17.81	A-2-6(0)	27	11	34.5	39.5	6.8	19.2	97	79	29	-	-	

EB1-B

SOIL TEST RESULTS																
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%	
							C.SAND	F.SAND	SILT	CLAY	10	40	200			MOISTURE
SS-22	3.7M RT	12+57.6	6.89-7.34	A-2-7(3)	42	25	31.1	38.4	2.2	28.3	100	88	34	17.5	-	
SS-23	3.7M RT	12+57.6	14.49-14.94	A-2-4(0)	17	NP	62.8	23.4	3.6	10.1	100	74	14	-	-	
SS-24	3.7M RT	12+57.6	22.09-22.54	A-7-6(10)	41	17	10.7	36.2	30.9	22.2	100	95	66	34.2	-	
SS-25	3.7M RT	12+57.6	23.61-24.06	A-7-5(6)	44	11	11.7	42.2	36.0	10.1	99	94	60	-	-	

B1-A

SOIL TEST RESULTS																
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%	
							C.SAND	F.SAND	SILT	CLAY	10	40	200			MOISTURE
SS-26	3.4M LT	12+68.2	5.26-5.71	A-6(3)	34	19	27.7	39.2	6.9	26.3	99	87	38	20.0	-	
SS-27	3.4M LT	12+68.2	9.82-10.27	A-2-6(1)	35	18	38.8	32.5	2.4	26.3	100	81	29	22.9	-	
SS-28	3.4M LT	12+68.2	14.38-14.83	A-2-4(0)	19	NP	71.5	16.0	2.4	10.1	99	63	13	-	-	
SS-29	3.4M LT	12+68.2	20.46-20.91	A-7-6(13)	49	25	12.7	18.0	22.8	46.5	83	77	61	36.5	-	
SS-30	3.4M LT	12+68.2	21.98-22.43	A-7-5(17)	64	21	5.9	34.7	35.2	24.2	100	98	69	-	-	

B2-B

SOIL TEST RESULTS																
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%	
							C.SAND	F.SAND	SILT	CLAY	10	40	200			MOISTURE
SS-31	2.9M RT	13+05.2	0.32-0.77	A-7-6(7)	43	24	18.0	40.2	7.5	34.3	100	93	48	14.1	-	
SS-33	2.9M RT	13+05.2	13.40-13.85	A-6(7)	35	18	11.5	40.8	19.4	28.3	98	93	55	17.7	-	
SS-34	2.9M RT	13+05.2	13.40-13.85	A-5(8)	57	9	6.7	38.6	34.5	20.2	97	94	64	33.4	-	
SS-35	2.9M RT	13+05.2	19.48-19.93	A-5(0)	43	NP	24.2	44.6	27.1	4.0	90	77	38	-	-	

EB2-A

SOIL TEST RESULTS																
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%	
							C.SAND	F.SAND	SILT	CLAY	10	40	200			MOISTURE
SS-11	3.5M LT	13+16.5	2.25-2.70	A-2-4(0)	18	NP	32.4	51.3	9.2	7.1	100	86	23	-	-	
SS-12	3.5M LT	13+16.5	3.77-4.22	A-6(1)	30	11	24.8	39.4	7.5	28.3	100	91	41	-	-	
SS-13	3.5M LT	13+16.5	4.53-4.98	A-2-6(1)	35	17	27.1	49.1	4.6	19.2	100	88	29	21.2	-	
SS-14	3.5M LT	13+16.5	6.81-7.26	A-2-4(0)	19	NP	61.0	20.6	4.2	14.1	100	65	19	-	-	
SS-15	3.5M LT	13+16.5	9.85-10.30	A-2-4(0)	21	NP	59.9	25.7	1.3	13.1	100	80	15	-	-	
SS-16	3.5M LT	13+16.5	12.89-13.34	A-6(4)	32	14	28.7	25.9	21.2	24.2	100	83	51	-	-	
SS-17	3.5M LT	13+16.5	15.93-16.38	A-7-6(16)	44	28	10.3	28.9	14.3	46.5	100	95	66	19.0	-	
SS-18	3.5M LT	13+16.5	18.97-19.42	A-7-6(18)	47	31	9.9	29.3	14.3	46.5	99	94	66	25.0	-	

EB2-B

SOIL TEST RESULTS																
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%	
							C.SAND	F.SAND	SILT	CLAY	10	40	200			MOISTURE
SS-19	3M RT	13+21.7	4.53-4.98	A-6(3)	34	17	24.0	41.2	6.5	28.3	100	91	40	17.0	-	
SS-20	3M RT	13+21.7	6.81-7.26	A-2-6(0)	34	16	45.1	35.9	1.9	17.2	100	79	23	-	-	
SS-21	3M RT	13+21.7	9.85-10.30	A-2-6(1)	36	19	65.4	12.7	1.7	20.2	99	68	23	-	-	