

ALL WATER LINES AND SANITARY SEWER LINES OWNED BY THE CITY OF GASTONIA

PROP. 30M OF 200MM DI WATER PIPE, CLASS 51, 2.41 MPA WP
1 - 200MM GATE VALVE & VALVE BOX, 1.38 MPA WP
4- 200MM 22 1/2° DI BENDS
CONNECT USING NECESSARY FITTINGS

PROP. 1 - RELOCATE EXISTING FIRE HYDRANT
6M OF 150MM DI WATER PIPE, CLASS 51, 2.41 MPA WP
CONNECT USING NECESSARY FITTINGS

PROP. 5 - RELOCATE EXISTING WATER METERS
38M OF 20MM COPPER WATER PIPE, TYPE K
4 - 200MM X 20MM TAPPING SADDLES
4 - 20MM CORPORATION STOPS
CONNECT USING NECESSARY FITTINGS

PROP. 1 - RELOCATE EX. WATER METER
11M OF 20MM COPPER WATER PIPE, TYPE K
1 - 200MM X 20MM TAPPING SADDLE
1 - 20MM CORPORATION STOP
CONNECT USING NECESSARY FITTINGS

PROP. 29M - FILL OR REMOVE ABANDONED 200MM PIPE, CI WATER

PROP. 4 - CUT-IN SANITARY SEWER CLEAN-OUTS
CONNECT USING NECESSARY FITTINGS

PROP. 2 - CUT-IN SANITARY SEWER CLEAN-OUTS
CONNECT USING NECESSARY FITTINGS

PROP. 5 - RELOCATE EXISTING WATER METERS
112M OF 20MM COPPER WATER PIPE, TYPE K
5 - 200MM X 20MM TAPPING SADDLES
5 - 20MM CORPORATION STOPS
CONNECT USING NECESSARY FITTINGS

PROP. 2 - CUT-IN SANITARY SEWER CLEAN-OUTS
CONNECT USING NECESSARY FITTINGS

PROP. 3 - RELOCATE EX. WATER METERS
44M OF 20MM COPPER WATER PIPE, TYPE K
3 - 200MM X 20MM TAPPING SADDLE
3 - 20MM CORPORATION STOP
CONNECT USING NECESSARY FITTINGS

PROP. 2 - RELOCATE EXISTING SANITARY SEWER CLEAN-OUTS
20M OF 100MM PVC SEWER PIPE, SDR 21, 1.03 MPA
CONNECT USING NECESSARY FITTINGS

PROP. 51M OF 150MM DI WATER PIPE, CLASS 51, 2.41 MPA WP
1 - 200MM X 150MM DI TEE
1 - 150MM GATE VALVE & VALVE BOX, 1.38 MPA WP
2 - 150MM 22 1/2° DI BENDS
1 - 150MM DI PLUG TAPPED FOR 50MM PIPE
CONNECT USING NECESSARY FITTINGS

PROP. 13M OF 150MM DI WATER PIPE, CLASS 51, 2.41 MPA WP
2 - 150MM 45° DI BENDS
2- 150MM 22 1/2° DI BENDS
CONNECT USING NECESSARY FITTINGS

PROP. 1 - CUT-IN SANITARY SEWER CLEAN-OUT
CONNECT USING NECESSARY FITTINGS

MATCHLINE -L- STA 48+00 SHEET UC-20

MATCHLINE -L- STA 49+80 SHEET UC-22

MATCHLINE -Y23-

MATCHLINE -Y23-

C:\Users\jacobway\OneDrive\Documents\2408\U2408UC21.dwg
 10/07/2004 11:49:00 AM