

PROJ. NO. -8.2407701
ID NO. - B-3530
COUNTY - WAKE

EB1-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-5	16' LT	15+33	8.5-10.0	A-1-b(0)	22	NP	65.4	24.1	6.5	4.0	88	48	11	-	-

EB1-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-4	6' RT	15+33	8.5-10.0	A-4(1)	30	9	37.9	18.4	21.5	22.3	97	72	44	-	-

B1-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-6	16' LT	15+58	3.5-5.0	A-7-5(20)	70	38	24.5	16.8	16.2	42.5	94	81	58	-	-
SS-7	16' LT	15+58	8.5-9.3	A-6(11)	37	18	13.6	18.4	25.5	42.5	100	95	70	-	6.5
SS-8	16' LT	15+58	9.3-10.0	A-2-4(0)	17	NP	21.7	51.0	17.2	10.1	100	94	32	-	-
SS-9	16' LT	15+58	14.4-15.0	A-2-4(0)	22	NP	60.6	28.1	9.2	2.0	91	54	13	-	-

B1-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-12	5' RT	15+58	11.2-11.7	A-2-4(0)	29	NP	70.2	16.8	8.9	4.0	100	52	14	-	3.2

B2-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-11	16' LT	16+08	6.3-7.8	A-2-4(0)	20	5	45.1	24.9	11.7	18.2	93	66	31	-	-

EB2-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-10	16' LT	16+33	3.5-5.0	A-2-4(0)	16	NP	51.6	22.7	15.6	10.1	93	61	27	-	-

EB2-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-1	16' RT	16+33	0.0-2.3	A-2-4(0)	21	NP	62.8	21.3	9.9	6.1	94	51	17	-	-
SS-2	16' RT	16+33	3.5-4.3	A-2-4(0)	18	NP	61.1	19.4	9.3	10.1	95	52	21	-	-
SS-3	16' RT	16+33	4.3-5.0	A-6(5)	33	15	20.9	28.9	27.9	22.3	100	90	55	-	8.8