



**SOIL TEST RESULTS**

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	800
SS-7	CL	16+45	0.0-1.0	A-2-4(0)	27	7	38	36	12	14	86	71	27
SS-8	CL	16+45	3.8-5.0	A-2-5(0)	44	NP	31	51	10	8	98	88	23

BEGIN BRIDGE -L- STA. 16+20 +/-

