

### SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
S-6	30' RT	30+00	0.50-2.00	A-4(2)	27	10	19.1	33.7	22.8	24.4	95	87	50	-	-
S-12	31' RT	16+92	2.00-4.00	A-4(0)	21	2	27.1	39.0	19.8	14.1	100	93	39	-	-
SS-13	31' RT	16+92	4.00-7.00	A-4(5)	31	10	14.9	35.0	34.1	16.1	100	94	66	11.3	-

