



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	PL. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
SS-6	35	41+00	0.00-1.50	A-6(8)	39	19	18.3	30.6	11.0	40.2	98	91	55
SS-7	35	41+00	3.70-5.20	A-4(3)	27	9	4.8	47.2	21.8	26.1	100	99	61
SS-8	35	41+00	8.70-10.20	A-1-6(0)	19	NP	65.7	22.3	1.9	10.1	77	45	10
SS-9	35	41+00	13.70-15.20	A-4(0)	31	NP	20.3	51.5	16.2	12.1	97	89	37
S-4	0	42+00	0.00-2.00	A-6(6)	38	19	18.5	33.6	7.7	40.2	97	91	50
S-5	0	42+00	8.00-13.50	A-2-4(0)	19	5	25.7	47.4	10.8	16.1	98	89	32

TAN-GRAY, LOOSE TO MEDIUM DENSE, WET, FINE TO COURSE SAND WITH GRAVEL

RESIDUAL: TAN-GRAY AND BROWN, MEDIUM STIFF WET, SANDY SILT WITH SOME MICA