

EB1-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-10	16' LT	14+71	3.4-4.9	A-4(0)	24	8	35.5	25.9	20.6	18.0	97	73	42	-	-
SS-11	16' LT	14+71	8.4-9.9	A-4(0)	21	4	40.9	25.1	16.0	18.0	99	72	37	-	-

EB2-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-3	14' LT	16+03	3.0-4.1	A-7-6(9)	51	23	32.9	17.2	15.8	34.1	96	74	51	-	-
SS-4	14' LT	16+03	8.0-9.5	A-6(2)	34	13	37.5	28.1	12.4	22.0	94	68	43	-	5.2

EB1-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-1	15' RT	14+70	3.0-4.5	A-6(2)	27	12	34.3	23.2	16.4	26.1	96	73	44	-	-
SS-2	15' RT	14+70	8.0-9.5	A-4(3)	27	9	22.2	17.0	28.7	32.1	99	84	64	-	-

B1-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-5	15' LT	15+10	3.4-4.9	A-1-a(0)	25	NP	47.1	29.3	15.6	8.0	39	26	11	-	-
SS-6	15' LT	15+10	13.4-14.9	A-2-6(0)	33	13	66.7	21.0	8.2	4.0	57	28	9	-	-

B1-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-14	11' RT	15+11	3.2-4.7	A-2-4(0)	27	7	50.9	22.6	12.4	14.0	88	55	26	-	-
SS-15	11' RT	15+11	5.7-7.2	A-2-4(0)	16	NP	52.5	24.4	13.0	10.0	90	56	24	-	-

B2-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-12	14' LT	15+62	8.0-9.3	A-2-4(0)	28	8	55.3	18.0	10.6	16.0	96	62	27	-	-
SS-13	14' LT	15+62	13.8-14.5	A-2-4(0)	20	3	50.1	22.2	13.6	14.0	100	71	30	-	-

B2-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-7	12' RT	15+64	3.4-4.9	A-2-4(0)	21	3	48.3	22.4	15.2	14.0	86	55	28	-	-
SS-8	12' RT	15+64	8.4-9.6	A-2-6(0)	31	14	68.1	12.2	7.6	12.0	99	48	21	-	-
SS-9	12' RT	15+64	13.4-14.9	A-4(0)	20	5	22.4	34.3	21.2	22.0	100	89	47	-	-