



(A) ROADWAY EMBANKMENT, TAN-BROWN AND RED, MEDIUM STIFF, MOIST, SANDY SILT

18+50

18+00

17+50

17+00 -L-

SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	PL. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
S-8	0	18+50	1.00-2.00	A-6(5)	35	19	12.1	46.1	11.6	30.3	100	96	48
S-9	0	18+50	3.50-4.00	A-2-4(0)	27	4	24.6	44.8	10.3	20.2	100	94	33