



FIRE HYDRANT INSTALLATION DETAIL (UNPAVED AREAS)




- 1. RELOCATION SHALL INCLUDE THE REMOVAL AND INSTALLATION AT THE APPROPRIATE LOCATION OF THE WATER METER, METER SETTER AND YOKE, METER VALVES, AND METER BOX WITH LID.
- 2. THE NEW WATER SERVICE LINE SHALL BE OF THE SAME TYPE AND GRADE AS THE EXISTING WATER SERVICE LINE UNLESS OTHERWISE SHOWN ON THE PLANS OR DIRECTED BY THE ENGINEER.
- 3. THE NEW WATER SERVICE LINE SHALL BE INSTALLED WITH A MINIMUN OF 900mm COVER BELOW FINISHED GRADE.
- 4. THE OWNER RESERVES THE RIGHT TO ADD OR DELETE WATER SERVICE TAPS AND TO CHANGE LOCATIONS FROM THOSE SHOWN.

WATER METER RELOCATION DETAIL


		RENCH WIDTH OF PIPE	
NOMINAL PIPE SIZE (mm)	TRENCH WIDTH (meter)	NOMINAL PIPE SIZE (mm)	TRENCH WIDTH (meter)
102 152 203 254 305 356 406 457	0.72 0.76 0.81 0.86 0.91 0.97 1.02 1.07	508 610 762 914 1067 1219 1400	1.12 1.22 1.37 1.57 1.68 1.83 1.98




PAVEMENT REPAIR DETAIL



PIPE BEDDED IN 100mm MINIMUM LOOSE SOIL. TRENCH BACKFILLED IN LOOSE 150mm LAYERS COMPACTED TO TOP OF TRENCH USING LOCAL EXCAVATED MATERIAL IF APPROVED BY THE ENGINEER, OR SELECT MATERIAL ALL MATERIAL SHALL BE FREE OF ROCKS, FOREIGN MATERIAL, AND FROZEN EARTH. COMPACTION SHALL BE TO APPROX. 95% DENSITY IN ACCORDANCE WITH AASHTO T-99 AS MODIFIED BY THE DEPARTMENT OF TRANSPORTATION.



PIPE BEDDED IN LOOSE MATERIAL, LIGHTLY TAMPED WITH A MINIMUM OF 150mm UNDER PIPE. TRENCH BACKFILLED IN LOOSE 150mm LAYERS COMPACTED TO TOP OF TRENCH USING LOCAL EXCAVATED MATERIAL, IF APPROVED BY THE ENGINEER, OR SELECT MATERIAL. ALL MATERIAL SHALL BE FREE OF ROCKS, FOREIGN MATERIAL, AND FROZEN EARTH. COMPACTION SHALL BE TO APPROX. 95% DENSITY IN ACCORDANCE WITH AASHTO T-99 AS MODIFIED BY THE DEPARTMENT OF TRANSPORTATION.



PROJECT REFERENCE NO.

R-2552C

SHEET NO.

UC-25

VALVE MARKER DETAIL

NOTES:

- 1. VALVE MARKERS SHALL BE PLACED AT R/W.
- 2. LETTERS "MV" SHALL FACE TOWARDS VALVE.
- 3. MARKER SHALL HAVE BRASS OR BRONZE EMBED ON TOP OR SIDE.
- 4. CONTRACTOR SHALL STAMP DISTANCE TO CENTER OF VALVE INTO EMBED.
- 5. BLOW-OFF ASSEMBLY SHALL INCLUDE 1 EA. MARKER W/ "BO" OR "MV" CAST.



A Tyco International Ltd. Company
701 Corporate Center Drive, Suite 475
Raleigh, NC 27607
(919) 854–6200 – (919) 854–6259(fax)