

EB1-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-7	21.1 LT	78+08.0	0.79-1.24	A-7-6(11)	47	28	21.6	28.5	7.5	42.4	98	87	52	28.1	-
SS-8	21.1 LT	78+08.0	2.31-2.76	A-7-6(9)	47	28	7.1	47.9	8.7	36.4	100	98	48	-	-
SS-9	21.1 LT	78+08.0	3.83-4.28	A-2-4(0)	27	7	49.1	29.5	3.2	18.2	100	82	23	-	-
SS-10	21.1 LT	78+08.0	6.87-7.32	A-2-4(0)	20	NP	23.8	61.2	6.9	8.1	100	82	18	-	-
SS-11	21.1 LT	78+08.0	9.91-10.36	A-7-6(8)	41	20	5.3	52.5	13.9	28.3	93	90	54	33.6	-

EB2-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-21	20.8 LT	78+45.0	9.88-10.33	A-6(4)	29	17	2.0	62.6	11.1	24.211	100	98	48	32.1	-
SS-22	20.8 LT	78+45.0	12.92-13.37	A-5(0)	43	NP	15.2	49.5	31.3	4.0	93	87	41	35.6	-

EB1-C

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-88	CL	78+09.0	0.75-1.20	A-6(6)	37	20	24.4	31.5	5.8	38.3	100	88	48	26.7	-
SS-89	CL	78+09.0	2.27-2.72	A-2-7(2)	43	20	51.6	14.3	1.8	32.3	100	69	35	21.9	-
SS-90	CL	78+09.0	5.31-5.76	A-2-4(0)	18	NP	34.1	52.4	1.4	12.1	100	89	18	26.7	-
SS-91	CL	78+09.0	6.83-7.28	A-2-4(0)	19	NP	17.3	64.5	2.0	16.1	100	95	22	-	-
SS-92	CL	78+09.0	8.35-8.80	A-2-4(0)	19	NP	58.3	31.7	0.0	10.1	96	68	11	-	-

EB2-C

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-17	CL	78+52.8	0.79-1.24	A-6(2)	38	18	23.8	32.9	6.9	36.4	81	68	37	-	-
SS-18	CL	78+52.8	3.83-4.28	A-7-6(11)	46	27	5.1	43.8	12.7	38.4	100	99	53	28.4	-
SS-19	CL	78+52.8	5.35-5.80	A-2-4(0)	22	NP	45.3	40.8	2.8	11.1	100	85	16	-	-
SS-20	CL	78+52.8	9.91-10.36	A-1-b(0)	20	NP	85.9	7.0	2.1	5.1	79	23	6	-	-

EB1-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-1	21.1 RT	78+27.6	0.84-1.29	A-7-6(12)	46	31	20.6	30.1	6.9	42.4	100	90	52	26.1	-
SS-2	21.1 RT	78+27.6	2.36-2.81	A-7-6(9)	65	41	42.6	16.8	2.2	38.4	94	62	39	-	-
SS-3	21.1 RT	78+27.6	3.88-4.33	A-2-6(1)	34	16	33.7	38.6	3.4	24.2	100	83	29	-	-
SS-4	21.1 RT	78+27.6	5.40-5.95	A-2-4(0)	18	NP	26.3	51.5	6.1	16.2	100	94	26	-	-
SS-5	21.1 RT	78+27.6	9.96-10.41	A-1-b(0)	20	NP	72.7	16.5	3.7	7.1	83	38	10	-	-
SS-6	21.1 RT	78+27.6	11.48-11.93	A-7-5(29)	77	33	7.7	19.0	55.2	18.2	95	91	75	68.9	-

EB2-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-12	21.1 RT	78+62.0	0.81-1.26	A-7-6(9)	44	20	15.2	31.3	5.1	48.5	100	90	56	26.3	-
SS-13	21.1 RT	78+62.0	2.33-2.78	A-7-6(8)	61	40	48.1	15.2	4.4	32.3	100	65	38	-	-
SS-14	21.1 RT	78+62.0	8.41-8.86	A-3(0)	19	NP	78.2	13.6	1.1	7.1	98	59	8	-	-
SS-15	21.1 RT	78+62.0	9.93-10.38	A-6(6)	38	20	4.8	52.3	14.5	28.3	80	77	48	35.0	-
SS-16	21.1 RT	78+62.0	12.97-13.42	A-2-4(0)	27	NP	38.2	45.1	12.7	4.0	100	74	23	-	-