

EB1-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-118	7.0m RT	9+10.0	0.94-1.39	A-7-6(6)	41	18	28.0	24.6	9.2	38.3	98	83	49	-	-
SS-119	7.0m RT	9+10.0	2.46-2.91	A-7-6(46)	81	53	10.9	13.1	17.6	58.4	100	93	80	-	-
SS-120	7.0m RT	9+10.0	3.98-4.43	A-2-7(2)	47	24	53.8	16.1	5.9	24.2	85	57	27	-	-
SS-121	7.0m RT	9+10.0	5.50-5.95	A-6(1)	31	12	5.0	60.6	8.2	26.2	98	94	36	-	-
SS-122	7.0m RT	9+10.0	11.58-12.03	A-7-6(14)	46	22	9.1	47.5	23.3	20.1	98	91	68	-	-
SS-123	7.0m RT	9+10.0	13.10-13.55	A-5(0)	43	NP	6.8	52.2	34.9	6.0	100	98	54	-	-

BI-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-10	6.5m RT	9+32.0	2.72-3.17	A-2-4(0)	13	NP	45.5	32.5	3.7	18.3	99	72	25	-	-
SS-11	6.5m RT	9+32.0	4.24-4.69	A-7-6(20)	59	33	17.9	21.1	12.2	48.8	100	87	65	-	-
SS-12	6.5m RT	9+32.0	5.76-6.21	A-2-7(2)	47	28	59.3	13.4	0.8	26.4	87	52	25	-	-
SS-13	6.5m RT	9+32.0	7.28-7.73	A-6(2)	33	15	2.0	60.6	2.8	34.6	100	98	41	-	-
SS-14	6.5m RT	9+32.0	13.36-13.81	A-7-5(9)	52	22	10.2	36.4	25.0	28.5	83	78	53	-	-
SS-15	6.5m RT	9+32.0	16.40-16.85	A-4(0)	30	NP	2.8	51.2	31.7	14.2	100	98	60	-	-

EB2-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-162	7.0m LT	9+62.0	1.09-1.54	A-2-4(0)	19	NP	47.6	44.7	5.7	2.0	100	80	12	-	-
SS-163	7.0m LT	9+62.0	4.13-4.58	A-2-6(0)	31	14	57.8	20.9	5.1	16.1	95	56	22	-	-
SS-164	7.0m LT	9+62.0	7.17-7.62	A-6(5)	39	16	0.5	59.8	13.6	26.2	100	100	51	-	-
SS-165	7.0m LT	9+62.0	8.69-9.14	A-7-6(31)	60	39	4.2	40.0	27.6	28.2	99	96	77	-	-
SS-166	7.0m LT	9+62.0	11.73-12.18	A-7-5(24)	87	26	11.5	24.1	42.3	22.1	100	94	70	-	-