



SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	PL. I.	% BY WEIGHT				% PASSING SIEVES			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-245	CL	104+40	200-250	A-7-6(12)	48	21	2.4	36.7	20.5	40.4	99	98	64		
S-203	CL	104+40	400-1100	A-7-5(14)	52	20	4.0	30.7	32.9	32.3	95	93	68		

104+57.932
RESIDUAL CLAY

104+37.910
RESIDUAL: RED-BROWN TO BROWN, STIFF TO VERY STIFF, DRY TO MOIST
SLIGHTLY MICACEOUS SANDY SILTY CLAY, MEDIUM PLASTICITY

104+17.888
RESIDUAL SILT AND CLAY

103+97.865
RESIDUAL: RED-BROWN, VERY STIFF, DRY TO MOIST, MICACEOUS CLAY, HIGH PLASTICITY

RESIDUAL SILT AND CLAY

17.22.03

 SYSTEMS
