



SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	PL I.	% BY WEIGHT				% PASSING SIEVES			% MOISTURE	% ORGANIC
							G. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-303	12m RT	92+28	0.00-0.45	A-4(0)	24	NP	8.5	53.3	20.0	18.2	100	98	47	20.2	
SS-304	12m RT	92+28	1.73-2.23	A-5(1)	42	4	10.1	44.6	25.1	20.2	98	94	52		
SS-305	12m RT	92+28	4.06-4.51	A-5(2)	42	5	3.6	50.9	29.3	16.2	100	99	51	36.5	
SS-306	26m LT	92+20	0.28-0.45	A-2-4(0)	23	NP	21.2	51.7	8.9	18.2	87	77	29		
SS-307	26m LT	92+20	1.08-1.53	A-4(0)	40	NP	4.8	52.1	32.9	10.1	100	99	53	43.0	
SS-308	CL	93+00	0.00-0.91	A-4(0)	21	4	21.4	44.8	9.5	24.2	96	83	39		
SS-309	CL	93+00	1.75-2.00	A-7-5(17)	63	15	1.6	26.9	25.1	46.5	100	99	78		

Ⓜ ALLUVIAL: RED-BROWN TO GRAY, VERY SOFT, MOIST TO WET, SANDY SILT AND VERY LOOSE SILTY SAND

