


SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	PL I.	% BY WEIGHT				% PASSING SIEVES			MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-282	15m LT	84+00	0.00-0.45	A-2-4(O)	39	NP	42.4	41.6	12.0	4.0	82	59	17		
SS-283	15m LT	84+00	1.35-1.80	A-5(O)	43	NP	5.4	57.1	25.3	12.1	91	90	44	45.6	5.2
SS-284	15m LT	84+00	2.11-2.56	A-5(O)	41	NP	6.3	52.3	29.4	12.1	100	99	51		
SS-285	15m LT	84+00	4.39-4.84	A-5(O)	47	NP	8.5	43.6	35.8	12.1	100	99	56	47.7	
SS-286	22m RT	84+40	0.00-0.45	A-5(O)	46	NP	15.1	52.7	24.1	8.1	95	90	53		
SS-287	22m RT	84+40	0.95-1.40	A-5(2)	51	5	9.7	50.9	29.4	10.1	100	97	37		
ST-15	22m RT	84+40	1.60-2.21	A-7-5(III)	67	17	4.0	44.0	37.8	14.1	96	94	59	50.8	
SS-288	22m RT	84+40	2.47-2.92	A-7-5(IV)	68	20	4.2	39.4	22.6	20.2	100	98	65	75.1	

- (FF) ALLUVIAL: GRAY, VERY LOOSE, WET, SILTY SAND WITH A TRACE OF ORGANICS
- (GG) COASTAL PLAIN: GRAY TO TAN, VERY LOOSE, WET, SILTY SAND AND GRAVEL
- (HH) ALLUVIAL: BROWN-GRAY, SOFT, MOIST TO WET, SANDY SILT WITH A TRACE OF ORGANICS



\*\*\*\*\*SYTIME\*\*\*\*\*  
\*\*\*\*\*DOWNS\*\*\*\*\*  
\*\*\*\*\*\*\*\*\*\*