
	PROJECT REFERENCE NO.	SHEET NO.
	R-2552B	33A
	ROADWAY DESIGN ENGINEER	HYDRAULICS ENGINEER
<b>PRELIMINARY PLANS</b> DO NOT USE FOR CONSTRUCTION		
CONST. REV. -----		
R/W REV. -----		

**SOIL TEST RESULTS**

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL.	PL. I.	% BY WEIGHT				% PASSING SIEVES			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-233	CL	102+40	0.95-1.40	A-6(2)	31	11	12.1	44.8	14.5	28.6	97	92	47		
SS-234	CL	102+40	2.47-2.92	A-7-5(6)	55	13	6.5	50.9	30.3	12.3	100	98	53	58.9	
SS-235	CL	102+40	5.51-5.96	A-7-5(2)	48	11	11.2	54.6	26.0	8.2	100	98	43	44.7	
SS-236	CL	102+40	8.57-9.02	A-4(0)	30	NP	13.3	55.6	24.9	6.1	100	95	44	17.2	
SS-230	CL	103+20	1.20-1.65	A-4(0)	37	NP	22.3	47.6	11.7	18.4	100	92	38	10.4	
SS-231	CL	103+20	2.72-3.17	A-2-4(0)	29	NP	37.0	41.3	13.5	8.2	100	96	27	9.2	
SS-232	CL	103+20	4.24-4.69	A-2-4(0)	37	NP	30.7	44.8	14.3	10.2	100	99	30		
SS-196A	CL	102+00	1.02-1.47	A-7-5(15)	64	20	15.6	23.0	33.1	28.3	100	91	66		
SS-197	CL	102+00	2.54-2.99	A-7-5(13)	55	15	9.9	22.8	49.1	18.2	100	95	73		
SS-198	CL	102+00	4.06-4.51	A-7-5(17)	58	17	5.1	21.6	53.1	20.2	100	98	78		
SS-199	CL	103+60	0.70-1.15	A-7-5(36)	80	42	4.8	23.2	11.3	60.6	100	98	76		
SS-200	CL	103+60	2.22-2.67	A-5(3)	43	8	8.7	47.1	26.1	18.2	100	97	52		
ST-9	CL	103+60	4.40-4.61	A-5(1)	44	7	11.1	52.9	21.9	14.1	100	96	46		
RT-6	CL	103+60	4.20-5.26	A-7-5(7)	50	15	8.4	45.5	17.7	28.5	100	97	54		
SS-201	CL	103+60	6.78-7.23	A-5(2)	50	NP	12.7	34.5	40.4	12.1	100	92	60		
CBR-7	CL	103+60	7.23-10.20	A-7-5(9)	50	18	11.2	36.8	19.6	32.5	97	91	57		
SS-202	CL	103+60	9.82-10.27	A-5(0)	48	NP	16.0	39.5	36.6	8.1	100	93	51		

SYSTEM\$\$\$\$  
 USER\$\$\$\$  
 DGN\$\$\$\$  
 PLOT\$\$\$\$