



### SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
SS-198	0	10+40	1.11-1.56	A-2-4(0)	27	NP	48.8	31.5	3.5	16.1	96	69	25
SS-199	0	10+40	2.63-3.08	A-7-6(17)	60	36	9.5	37.7	6.4	46.4	100	96	56
SS-500	0	10+40	4.15-4.60	A-2-7(3)	45	24	37.3	29.6	2.8	30.2	100	89	34

SS-198  
SS-199  
SS-500

