

20

10


0

10

20

30

40



PROJECT REFERENCE NO.
R-2552C

SHEET NO.
115 OF 126

SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
SS-289	0	7+95	0.97-1.42	A-7-6(14)	49	25	5.4	42.7	11.7	40.2	100	96	62
SS-290	0	7+95	2.49-2.94	A-7-6(23)	56	32	0.8	38.2	12.7	48.3	100	100	73
SS-291	0	7+95	4.01-4.46	A-7-6(21)	50	26	3.6	40.0	14.1	42.3	99	97	79
ST-1	0	7+95	4.47-5.08	A-7-5(9)	56	24	19.7	25.5	20.7	34.1	75	65	49

