

SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL.	PL. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
S- 751	5	110+70	0.50-1.05	A-6(1)	28	12	29.2	34.1	12.3	24.4	95	81	40
S- 752	5	110+70	2.50-3.05	A-7-6(6)	41	25	26.2	31.5	13.9	28.4	95	83	44
SS- 58	27.5	110+64	1.16-1.61	A-2-4(0)	25	NP	34.2	45.7	2.8	17.3	100	88	24
SS- 59	27.5	110+64	2.68-2.83	A-2-4(0)	24	NP	50.9	35.4	7.6	6.1	81	54	15
SS- 546	28	110+90	1.15-1.60	A-7-5(33)	67	31	4.5	11.8	36.9	46.8	100	98	87
SS- 547	28	110+90	2.67-3.12	A-7-5(21)	61	26	14.2	16.9	48.5	20.3	100	94	73
SS- 548	28	110+90	4.19-4.64	A-7-5(15)	59	20	20.3	14.2	45.1	20.3	100	88	67
SS- 549	28	110+90	8.75-9.20	A-2-4(0)	40	8	37.8	19.7	30.2	12.2	50	36	24

