



NOTE

-PROVIDE A 50 MM SPACE BETWEEN THE CONTROLLER AND THE ROLL OUT DRAWER TO ACCOMMODATE A FIBER INTERCONNECT CENTER.

332A CABINET
LEFT SIDE

332A CABINET

332A CABINET
RIGHT SIDE

REAR VIEW

Typical Drawing

	Cabinet Component Layout 170 Cabinet Model 332A with 2070L Controller		
	PLAN DATE: October 2002	REVIEWED BY:	
PREPARED BY: P L Alexander	REVIEWED BY:	INIT. DATE	SIGNATURE: <i>Milton I. Deane</i> DATE: 11/13/02
222 N. McDowell St., Raleigh, NC 27603		SIG. INVENTORY NO.	NA

13-NOV-2002 10:51
US:ccadent10 cad1net1.dgn
PLOT:ccadent