



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S- 19	CL	19+00	3.00- 3.45	A- 7- 5(3)	44	12	27.0	33.3	15.4	24.2	100	85	46	-	-
SS- 20	CL	19+60	0.93- 1.38	A- 4(0)	38	6	40.6	23.0	14.2	22.2	98	70	39	-	-
SS- 21	CL	19+60	2.46- 2.90	A- 2- 4(0)	39	5	43.4	24.4	12.0	20.2	91	61	34	-	-
SS- 22	CL	19+60	3.97- 4.42	A- 2- 5(0)	41	NP	49.4	21.4	15.0	14.1	100	61	33	-	-