



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-381	30 RT	15+60	0.15-1.12	A-7-6(7)	43	23	32.5	22.0	11.1	34.3	100	83	48	-	-
SS-385	CL	15+60	1.27-1.72	A-5(5)	52	10	24.0	30.7	25.1	20.2	100	85	53	-	-
SS-386	CL	15+60	2.79-3.24	A-7-5(4)	49	13	25.5	38.0	8.3	28.3	100	85	47	-	-
S-387	CL	15+00	0.15-1.00	A-7-6(7)	44	25	34.9	23.2	13.5	28.3	100	81	45	-	-
SS-379	30 RT	15+00	1.31-1.76	A-7-5(21)	61	29	16.8	16.8	28.1	38.4	100	91	70	-	-
SS-380	30 RT	15+00	2.83-3.28	A-4(0)	39	NP	27.5	33.7	26.7	12.1	100	86	44	-	-

 05/21/2008 10:00 AM
