



### SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-232	CL	20+80	0.00-1.80	A-6(1)	28	12	39.4	26.0	12.5	22.1	100	76	39	-	-
S-233	CL	20+80	1.80-3.50	A-7-6(13)	53	28	29.0	18.3	16.5	36.2	100	81	56	-	-
S-234	CL	20+20	2.10-3.10	A-7-6(16)	56	31	24.7	18.3	14.7	42.3	100	84	60	-	-
S-235	CL	20+20	0.00-2.10	A-7-6(13)	61	35	32.4	20.3	9.1	38.2	100	82	50	-	-
S-295	CL	18+10	0.00-1.50	A-2-4(0)	16	NP	46.7	31.8	9.5	12.1	98	71	26	-	-
S-255	CL	18+10	1.50-3.00	A-6(1)	30	13	41.4	24.3	10.1	24.1	100	72	37	-	-
S-256	CL	18+10	3.00-4.11	A-6(2)	32	14	41.0	20.5	12.3	26.2	95	66	40	-	-
S-370	CL	13+71	1.30-1.70	A-7-5(28)	67	35	11.9	17.8	25.9	44.4	100	96	74	-	-
S-371	CL	14+20	3.00-3.40	A-7-5(18)	56	23	17.0	14.3	34.3	34.3	100	92	72	-	-
SS-379	CL	14+80	1.31-1.76	A-7-5(21)	61	29	16.8	16.8	28.1	38.4	100	91	70	-	-
SS-380	CL	14+80	2.83-3.28	A-4(0)	39	NP	27.5	33.7	26.7	12.1	100	86	44	-	-
S-381	CL	15+40	0.15-1.12	A-7-6(7)	43	23	32.5	22.0	11.1	34.3	100	83	48	-	-
S-382	CL	17+20	3.70-4.14	A-6(5)	40	12	26.9	25.7	27.3	20.2	100	82	54	-	-
SS-460	CL	18+45	0.15-0.55	A-4(0)	22	5	36.7	30.5	16.7	16.1	97	76	37	-	-
SS-461	CL	18+45	1.04-1.49	A-7-6(7)	49	32	38.4	23.3	10.2	28.1	99	70	41	-	-
SS-462	CL	18+45	2.56-3.01	A-6(1)	36	11	41.2	24.9	15.9	18.1	96	69	38	-	-
SS-463	CL	18+45	4.08-4.53	A-2-4(0)	28	NP	45.2	33.7	15.1	6.0	93	68	26	-	-
S-464	CL	19+60	0.15-1.00	A-7-5(21)	65	34	23.7	16.3	15.9	44.2	100	84	63	-	-
S-465	CL	19+00	0.15-2.00	A-7-6(13)	51	23	24.5	16.9	20.5	38.2	100	83	62	-	-
S-466	CL	19+00	3.00-4.00	A-7-6(9)	46	22	29.9	22.3	23.7	24.1	100	80	53	-	-
SS-479	CL	17+70	1.03-1.48	A-4(0)	30	NP	40.8	26.1	21.1	12.0	98	75	37	-	-
SS-480	CL	17+70	4.07-4.52	A-2-4(0)	27	NP	49.6	27.3	17.1	6.0	97	63	28	-	-