



### SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-500	5 RT	14+60	0.15-0.45	A-4(0)	33	6	32.8	28.2	18.7	20.3	95	76	41		
S-501	5 RT	14+60	0.50-0.75	A-7-6(6)	44	19	31.0	23.1	17.5	28.4	94	76	48		
SS-504	5 RT	14+60	2.55-2.75	A-4(0)	25	8	35.1	29.4	13.3	22.3	97	78	39		
SS-505	5 RT	14+60	3.21-3.40	A-2-4(0)	19	NP	51.7	30.4	7.8	10.1	97	69	21		
S-94	10M LT	14+40	0.00-0.23	A-7-5(40)	69	34	0.6	6.5	42.4	50.5	100	100	96	-	-

