



SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-371	30RT	14+40	3.00-3.40	A-7-5(18)	56	23	17.0	14.3	34.3	34.3	100	92	72	-	-
S-376	CL	14+40	0.15-1.10	A-7-5(33)	73	42	16.0	12.5	45.3	26.3	100	91	74	-	-
S-377	CL	14+40	2.66-4.18	A-7-6(9)	47	18	23.8	25.3	40.8	10.1	100	88	57	-	-
S-378	CL	14+40	5.00-5.70	A-4(1)	38	NP	28.1	36.8	25.1	10.1	100	84	44	-	-

