



### SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-37	CL	27+30	0.66-1.11	A-7-6(9)	46	23	28.0	21.5	6.2	44.3	100	86	54	-	-
SS-38	CL	27+30	2.18-2.63	A-5(2)	41	9	29.0	33.6	13.3	24.1	100	83	44	-	-
SS-39	CL	27+30	3.70-4.15	A-4(0)	37	NP	29.6	38.8	13.5	18.1	100	82	40	-	-
SS-40	CL	27+30	5.22-5.67	A-2-4(0)	36	NP	37.6	35.2	11.1	16.1	100	75	33	-	-
SS-41	CL	27+30	9.78-10.23	A-2-4(0)	32	4	42.7	32.6	10.7	14.1	100	71	31	-	-
SS-63	CL	25+40	1.36-1.81	A-2-4(0)	28	NP	45.7	29.1	15.2	10.1	96	65	30	-	-
SS-64	CL	25+40	2.88-3.33	A-2-4(0)	33	NP	49.7	29.1	15.2	6.1	96	61	25	-	-
SS-267	CL	10+60	0.15-0.60	A-2-4(0)	20	7	40.6	29.4	11.9	18.1	100	74	34	-	-
SS-268	CL	10+60	1.10-1.55	A-2-6(0)	33	11	45.3	26.8	7.8	20.1	98	66	32	-	-
SS-269	CL	10+60	2.94-3.07	A-7-6(4)	43	20	41.4	20.7	15.7	22.1	96	67	40	-	-
SS-270	CL	10+60	4.14-4.59	A-2-4(0)	36	NP	48.5	29.8	13.7	8.0	97	62	27	-	-
S-271	2 LT	11+37	0.10-0.70	A-6(3)	39	18	36.2	24.5	9.1	30.2	94	73	40	-	-
S-272	2 LT	11+37	1.40-1.75	A-7-6(5)	42	14	32.2	18.7	20.9	28.2	100	78	53	-	-
S-273	2 LT	11+37	2.00-2.62	A-6(4)	38	14	32.0	21.1	18.7	28.2	100	79	51	-	-
S-274	2 LT	11+37	3.10-4.14	A-4(1)	39	10	42.1	19.7	18.1	20.1	97	67	41	-	-
S-281	CL	12+00	0.15-2.98	A-7-5(7)	50	13	27.6	18.5	17.7	36.2	100	82	57	-	-
SS-458	CL	12+60	1.10-1.55	A-4(1)	37	10	37.3	25.3	21.3	16.1	99	76	41	-	-